



FIRE SAFETY CERTIFICATE

Certified that the **M/S Drool Fresh Restaurant at ground floor, Metro Commercial Space, Metro Station Sector - 13, Dwarka, New Delhi - 110075** in a building comprised of ground + 1st floor (Platform Area) but Restaurant running at ground floor only, owned / occupied by **Drool Hospitality Private Limited** was earlier granted FSC by this department vide letter No. F6/DFS/MS/SZ/2022/EH/02 dated 06/01/2022. The premise was re-inspected by the officer concerned of this department on 02/07/2025 in the presence of Mr. Ravinder Kumar Dhankhar (Director) and found that the said premises has deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Group - D "**Assembly Building**" Restaurant at ground floor only with effect from 10/07/2025 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued 10/07/2025 at New Delhi by.

(ATUL GARG)
DIRECTOR

01/07/2025
DELHI FIRE SERVICE

Copy to: -

1. The Commissioner, MCD, Civic Center, J.L.N. Marg New Delhi - 110002: with a request to ensure the occupancy as detailed above and deviation if any. MCD portal ID - 2025061910292 dated 21/06/2025.
2. The Joint Commissioner of Police (Lic.), Ist Floor, P.S Defence Colony, New Delhi-24 w.r.t.- MCD portal ID - 2025061910292 dated 21/06/2025.
3. The Director, Drool Fresh Restaurant at ground floor, Metro Commercial Space, Metro Station Sector - 13, Dwarka, New Delhi - 110075.

Conditions for the validity of fire safety certificate

1. **Fire Safety Certificate is valid for ground floor only.**
2. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. The trained firefighting staff should be available round the clock.
5. Any deviation w. r. t. construction etc. shall be verified by the concerned building sanctioning authority.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

INSPECTION REPORT


1	Name & address of the building	M/s Drool Fresh restaurant at ground floor, Metro commercial space, Metro Station Sector-13, Dwarka, New Delhi - 110075.		
2	Building is comprised of	Ground + 1 st floor (Platform Area) But Restaurant running on ground floor only.		
3	Type of occupancy	Assembly Building, Group - D		
4	Type of case	Renewal Case		
5	Details of previous FSC	F6/DFS/MS/SZ/2022/EH/02 dated 06/01/2022		
6	Fire safety directives letter no.	N/A		
7	Date of inspection	02.07.2025		
8	Name of the inspecting officers	Yashwant Singh Meena, ADO/ Laxmi Nagar		
9	Name of the designation of officer from the building side	Mr. Ravinder Kumar Dhankhar (Director)		
10	Year of construction	2006		
11	Applicant's letter no.	MCD Application I.D No. 2025061910292 dated 21/06/2025		
S.No	Minimum standard of fire prevention and fire safety U/R 33	Requirement/ Existing fire safety arrangements	Provided at site	Remarks MR/NMR Old case
1	Access to Building:			
	A Road width	Required	20 mtr.	MR
	B Gate width	4.5 mtr.	Directly accessible from road	MR
	C Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits:			
	A Number of staircases			
	a Upper floor	N/A	N/A	N/A
	c Basement	N/A	N/A	N/A
	B Width of staircases			
	a Upper floor	N/A	N/A	N/A
	b Basement	N/A	N/A	N/A
	C Protection of exits		N/A	N/A
	a Fire check door	N/A	N/A	N/A
	b Pressurization	N/A	N/A	N/A
	D No. of continuous staircases to terrace	N/A	N/A	N/A
	E Width of corridor	N/A	N/A	N/A
	F Door size	1.5 mtr.	Provided	MR
3	Compartmentation:			
	A Fire check door	N/A	Provided	N/A
	B Sealing of electrical shafts	N/A	N/A	N/A
	C Fire rating of shaft door	N/A	N/A	N/A
	D Water curtain	N/A	N/A	N/A
	E Fire dampers	N/A	N/A	N/A
4	Smoke Management System:			
	A Basement	N/A	N/A	N/A
	B Upper floor	12ACPH	Provided	MR

5. Fire Extinguisher:				
A	Total numbers	04 nos.	04 nos.	MR
B	Types	CO ₂ & ABC	CO ₂ & ABC	MR
C	ISI marking	ISI Marked	ISI Marked	MR
6 First-Aid-Hose Reel: Provided in the metro station				
A	Total numbers of each floor	01 no.	01 no.	MR
B	Length of hose reel hose	30 m	30 m	MR
C	Nozzle diameter	05 mm	05 mm	MR
7 Automatic Fire Detection and Alarming System: Provided in the metro station				
A	Type of detectors	N/A	Provided	N/A
B	Location of main panel	N/A	Provided	N/A
C	Location of repeater panel	N/A	N/A	N/A
D	Alternate source of power	N/A	Battery backup	N/A
E	Hooters Location	Required	Provided	MR
8 MOEFA:		Required	Provided	MR
9 Public Address System:		N/A	N/A	N/A
10 Automatic Sprinkler System: Provided in the metro station				
A	Basement	N/A	N/A	MR
B	Upper floor	N/A	Provided	N/A
C	Sprinkler above false ceiling	N/A	N/A	N/A
11 Internal Hydrants:				
A	Size of riser/down-comer	100 mm	Provided	MR
B	Number of hydrants per Branch	Required	Provided	MR
C	Hose box	Required	Provided	MR
12 Yard Hydrants: Provided in the metro station				
A	Total number of hydrants	N/A	Provided	N/A
B	Hose box	N/A	Provided	N/A
13 Pumping Arrangements: Provided in the metro station				
1 Ground level				
A	Discharge of main pump	1800 LPM	1800 LPM	MR
B	Head of main pump	70 m	70 m	MR
C	Number of main pumps	01 no.	01 no.	MR
D	Jockey pump out put	180 LPM	180 LPM	MR
E	Jockey pump head	70 m	70 m	MR
F	Standby pump out put	1800 LPM	1800 LPM	MR
G	Standby pump head	70 m	70 m	MR
H	Auto starting /manual stopping	Required	Provided	MR
2 Terrace Level				
A	Discharge of pump	N/A	N/A	N/A
B	Head of the pump	N/A	N/A	N/A
C	Power supply	N/A	N/A	N/A
D	Auto starting of pump	N/A	N/A	N/A


14	Captive Water Storage for Fire Fighting:			Provided in the metro station	
	A	Underground tank capacity	N/A	1,00,000 liters	N/A
	B	Draw-off connection	N/A	Provided	N/A
	C	Fire service inlet	N/A	Provided	N/A
	D	Access to tank	N/A	Provided	N/A
	E	Overhead tank capacity	N/A	N/A	N/A
15	Exit Signage:			Required	Provided
16	Provision of Lifts:			Provided in the metro station	
	A	Pressurization of lift shaft	N/A	Provided	N/A
	B	Pressurization of lift lobby	N/A	Provided	N/A
	C	Communication in lift car	N/A	Provided	N/A
	D	Firemen's grounding switch	N/A	Provided	N/A
	E	Lift signage	N/A	Provided	MR
17	Standby Power Supply:			Required	Provided
18	Refuge Area:			Provided in the metro station	
	A	Total area	N/A	Provided	N/A
	B	Location	N/A	Provided	N/A
19	Fire Control Room:			Provided in the metro station	
	A	Detector system panel	N/A	Provided	N/A
	B	Flow switch panel	N/A	Provided	N/A
	C	PA system panel	N/A	Provided	N/A
	D	Battery backup	N/A	Provided	N/A
	E	Building floor plans	N/A	Provided	N/A
20	Special Fire Protection systems for protection of special Risks, if any:				


The fire protection system was randomly checked and tested and was found functional at the time of inspection.

Keeping in view the compliance of the minimum standards of fire prevention and fire safety measures as required under the rules. The FSC issued vide letter no. F6/DFS/MS/SZ/2022/EH/02 dated 06/01/2022 renewal under rule 35 (6) of the Delhi Fire Service rules 2010 is recommended.


 Signature of the Inspecting Officer
 Name: Yashwant Singh Meena
 Designation: ADO /Laxmi Nagar

D.O/SW


 3/7/25

CRO | 4/7/2025


Director