

c/82

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/GH/NDZ/ 123

Dated:-19/03/2025

To,

The Manager
M /s Drum of Heaven at S-14, Green Park
Extension, New Delhi-110016.

**Sub: Issuance of FSC (Fire Safety Certificate) in r/o M /s Drum of Heaven at S-14, Green Park
Extension, New Delhi-110016.**

Sir,

This has reference to online id no.2025022102237 dated 22.02.2025, on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 13/03/25 in the presence of Mr. Karamjeet and following shortcomings were observed:-

1. Alternate staircase found removed.
2. Pumps found nonfunctional.
3. Hydrant and hose reel found nonfunctional and nozzle also found missing.

Hence, the case is rejected and Fire Safety Certificate (FSC) cannot be renewed at this stage due to above shortcomings. Therefore, you are requested to rectify the above shortcomings and re-submit for further consideration in the matter.

Yours faithfully,


(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to:

1. The Joint commissioner of Police (Lic.) First floor, PS Defence Colony New Delhi.