

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001


Dated...03/06/2025

No.F.6/DFS/MS/EH/2025/SZ/222

FIRE SAFETY CERTIFICATE

Certified that **M/s Drums of Heaven** located at **S-14, Green Park Extension, New Delhi 110016** comprised of Basement (Storage), Ground, Mezzanine + 02 upper floors but **restaurant running on ground and Mezzanine floor only** owned/occupied by Karamjit Singh Puri was issued Fire Safety Certificate by this department vide letter no. F6/DFS/MS/EH/SZ/2022/52 Dt. 28/02/2022. The restaurant premise was re-inspected by the officer concerned of this department on 24/05/2025 in the presence of Mr. Ajit Sharma (Manager) and found that the said premise have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy **Class D "Assembly Building" (Restaurant at Ground & Mezzanine)** and **Validity upto 31/03/2028** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 03/06/2025 at New Delhi by


(VIRENDRA SINGH)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Copy to: -

1. The Addl. Commissioner of Police, (Lic/Branch) 1st Floor PS Defence Colony, New Delhi 110049 (Ref. MCD Portal ID 2025050507868 dated 05/05/2025)

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

INSPECTION REPORT

1	Name & Address of the Building	M/s Drums of Heaven at S-14, Green Park Extension, New Delhi 110016		
2	Type of Occupancy	Group-D-4 Assembly (Restaurant at GF & Mezz. Floor)		
3	Building Comprised of	Basement, Ground, mezzanine + 02 upper floor		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/EH/SZ/2022/52 Dt. 28/02/2022		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	24/05/2025		
8	Name of the Inspecting Officers	Sh. Suman Kumar, ADO		
9	Name & Designation of Officers from the building side	Mr. Ajit Sharma (Manager)		
10	Year of construction	1984		
11	Applicant letter No.	MCD Portal ID 2025050507868 dated 05/05/2025		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC Requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	Road width	4.5 mtr	Provided	MR
	Gate width	N/A	N/A	N/A
	Width of internal road	N/A	N/A	N/A
2	Number, width, type & arrangement of exits.			
	a. Number of Staircase			
	Upper floors.	02 No's	02 Nos	MR
	Basement floor.	02 No's	02 Nos	MR
	b. Width of Staircase			
	Upper floors	1.25 mtr each	1.20m & 1.0 m	MR(old case)
	c. Basement floor	1.25 mtr each	1.0 & 0.90 mtr	MR(old case)
	d. Protection of exits			
	Fire check door	N/A	N/A	N/A
	e. Pressurization	N/A	N/A	N/A
	f. No. of continuous staircase to terrace	Required	01 Provided	MR
	g. Width of corridor	N/A	N/A	N/A
	h. Door size	2 exits	02 exit provided	MR
3	Compartmentation.			
	Fire check door.	N/A	N/A	N/A
	Sealing of electrical shafts.	N/A	N/A	N/A
	Fire rating of shaft door.	N/A	N/A	N/A
	Water curtain	N/A	N/A	N/A
	Fire dampers.	N/A	N/A	N/A
4	Smoke Management system.			
	Basement	30 ACPH	Exhaust fan	MR
	Upper floors	12 ACPH	Exhaust fan	MR
5	Fire Extinguishers.			
	Total numbers	08 Nos	10 Nos	MR
	Types	ABC/CO ₂	ABC & CO ₂	MR
	ISI Marking	ISI marked	Provided	MR
6	First Aid Hose Reels.			
	Total numbers on each floor.	One	Provided	MR
	Length of hose-reel hose.	30m	Provided	MR
	Nozzle Diameter	5mm	Provided	MR
7	Automatic fire detection & alarming system.			
	Type of detectors	N/A	N/A	N/A
	Location of Main Panel	N/A	N/A	N/A
	Location of Repeater Panel	N/A	N/A	N/A

	Alternate source of power	N/A	N/A	N/A
	Hooter's location	N/A	N/A	N/A
8	MOEFA	Required	Provided	MR
9	Public Address System	N/A	N/A	N/A
10	Automatic Sprinkler System			
	Basement	Required	Provided	MR
	Restaurant area	N/A	N/A	N/A
	Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants.			
	Size of Riser/Down-comer	100 mm	Provided	MR
	Number of Hydrant per floor	One	Provided	MR
	Hose box.	One	Provided	MR
12	Yard Hydrants.			
	Total number of hydrants.	N/A	N/A	N/A
	Hose box.	N/A	N/A	N/A
13	Pumping arrangements.			
	Ground Level			
	Discharge of main pump.	N/A	N/A	N/A
	Head of main pump.	N/A	N/A	N/A
	Number of main pumps.	N/A	N/A	N/A
	Jockey Pump output.	N/A	N/A	N/A
	Jockey Pump head.	N/A	N/A	N/A
	Standby Pump output.	N/A	N/A	N/A
	Standby Pump head.	N/A	N/A	N/A
	Auto Starting/Manual Stopping.	N/A	N/A	N/A
	Pump house access.	N/A	N/A	N/A
	Terrace Level			
	Discharge of pump.	450 & 180 LPM	Provided	MR
	Head of pump.	35m	Provided	MR
	Power supply.	Required	Provided	MR
	Auto starting of pump.	Required	Provided	MR
14	Captive water storage for fire fighting.			
	Underground tank capacity.	N/A	N/A	N/A
	Draw-off connection.	N/A	N/A	N/A
	Fire Service Inlet.	Required	Provided	MR
	Access to tank.	N/A	N/A	N/A
	Overhead tank capacity.	5,000 Ltrs	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	Pressurization of lift shaft.	N/A	N/A	N/A
	Pressurization of lift lobby.	N/A	N/A	N/A
	Communication in lift car.	N/A	N/A	N/A
	Fireman's switch.	N/A	N/A	N/A
	Lift signage.	N/A	N/A	N/A
17	Standby Power Supply	Required	Provided	MR
18	Refuge Area			
	Total area	N/A	N/A	N/A
	Location	N/A	N/A	N/A
19	Fire Control Room.			
	Detector system panel.	N/A	N/A	N/A
	Flow switch panel.	N/A	N/A	N/A
	PA system panel.	N/A	N/A	N/A
	Battery backup.	N/A	N/A	N/A
	Building floor plan.	N/A	N/A	N/A

20	Special Fire Protection System for the Protection of special Risk, if any.	N/A	N/A	N/A
----	--	-----	-----	-----

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Further, the party has complied all the observation / Shortcoming already issued & communicated by this department vide letter of even no 123 dated 19/03/2025.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/EH/SZ/2022/52 Dt. 28/02/2022, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

27/06/2025
Signature of the Inspecting Officer
Name: - Sh. Suman Kumar
Designation: - ADO

DO (SD)

27/06/2025
30/5/2025

DO (SD)

27/06/2025

(ADO Suman)

As approved, F.T. letter is put up for
Signature *27/06/2025*

27/06/2025

MS Cell

03/4/25