

214



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आजादी का
अमृत महोत्सव

No. F6/DFS/MS/WZ/2025/ College/113

Dated:- 18/09/2025

To,

The Director,
DSEU, Ranhola Campus,
Kunwar Singh Nagar, Ranhola,
Nangloi, Delhi-110041.

Subj.: Regarding renewal of Fire Safety Certificate in respect of DSEU Ranhola Campus, located at Kunwar Singh Nagar, Ranhola, Nangloi, Delhi-110041.

Sir,

Please refer to your Form 'J' dated nil, on the subject cited above. In this connection, it is to inform you that the above said building was inspected by the officer concerned of this department on 04/09/2025 in the presence of Sh. Satpal (I/C Estate) & Sh. Mohit (I/C Security). During inspection, it has been observed that the building is comprised of Ground + 03 Upper Floor. However, the following shortcoming has been observed:-

1. Fire extinguisher found empty.
2. First – Aid Hose Reels found non-functional.
3. Fire pump found non-functional.

In view of the above shortcomings, the application for renewal of Fire safety Certificate cannot be considered at this stage & rejected. You are advised to rectify the above mentioned shortcoming under intimation to this department for taking further necessary action.

Yours faithfully,


17/9/2025
Virendra Singh
Chief Fire Officer

18/09/25
D/C

Copy to:-

1. The Deputy Director, Delhi Municipal Corporation, Civic Centre, Minto Road, Delhi-110002.