



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

6-59  
प्राप्त  
पाठ  
सु. अ. स. वि. वि.

No. F.6/DFS/MS/School/2025/SZ/ 738

Dated: 18/09/2025

To

Sh. Virender Kumar (Chairman),  
Dwarka International School,  
(Radiant Education Society)  
Sector-12, Dwarka, New Delhi-110078

Sub: Issuance of Fire Safety Certificate for Addition/Alteration in existing building of Dwarka International School, Sector-12, Dwarka, New Delhi (School ID: 1821224).

Sir,

This has reference to your letter No. DIS/CIR/PRN/2025-26/123 Dtd 27/08/2025, received in this department vide outdoor diary No. 5348 dated 28/08/2025. In this connection, the premise was re-inspected by concerned officers of this department on 04/09/2025 in your presence to verify the compliance of fire safety recommendations issued vide letter No. F.6/DFS/MS/BP/2017/226 dated 28/07/2017. During the inspection, it was observed that school building comprises basement, ground and three upper floors only. The 4<sup>th</sup> floor has not yet been constructed.

The fire safety arrangements such as underground water storage tank, smoke exhaust system, hose-reel & hydrant, escape routes, automatic sprinkler system in the basement, fire pumps at ground & terrace etc. were found provided and functional. Further, the school building comprised of Basement, Ground + 03 upper floors has already been issued Fire Safety Certificate vide this office letter No. F.6/DFS/MS/SZ/2023/School/619 dated 06/09/2023 for a period of three years from the date of its issuance.

In view of the satisfactory compliance of the minimum standard on fire prevention and fire safety measures, the condition mentioned at serial no. 1 the Fire Safety Certificate stand withdrawn. However, other conditions of the said FSC shall remain unchanged and be adhered to.

Yours faithfully,

  
(Virendra Singh)  
Chief Fire Officer  
Delhi Fire Service  


Copy to: -

1. The Dy. Director (L&I), Building, Delhi Development Authority, Vikas Sadan, INA, New Delhi-110023.