C-36

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No.F.6/DFS/MS/GH/2026/SZ/ 751 Dated: 28/10/2026

FIRE SAFETY CERTIFICATE

Certified that the M/s. Dynamic Hospitality guest house located at Plot No. 16, Pocket-4, Sector- 23B, Dwarka, New Delhi- 110075, building comprised of basement, stilt, ground plus three upper floors, using basement (vacant), stilt (parking & reception) ground floor, 1st, 2nd and 3rd floor each having 06 guest rooms respectively (total 24 guest rooms only), owned/occupied by Dynamic Hospitality, have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010. and verified by the officer concerned of this department on dated 10.09.2026 in the presence of the Manager, and found that the building is fit for occupancy Class "Residential" (Guest House) (**24 guest rooms up to 3rd floor**) w.e.f. 28/10/2026 for a period of three years, in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed below.

Issued on 28/10/2026 at New Delhi.

22/10/26

(A.K.Malik)
Chief Fire Officer
Delhi Fire Service

Copy to: -

1 The Commissioner, MCD, Delhi: **for information regarding use of basement and with a request to ensure the occupancy as detailed above and deviation, if any.**
2 Online application Id 2026081910561 dated 20.08.2026.

Conditions for the validity of fire safety certificate: -

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape arrangements shall be kept unlocked & unobstructed for speedy evacuation of occupants in case of an emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. Presently basement is vacant and not in use.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

N/3

INSPECTION REPORT

1. Name & address of the building : M/s. Dynamic Hospitality guest house at Plot No. 16, Pocket-4, Sector- 23B, Dwarka, New Delhi- 110075.
2. Building is comprised of : Basement (vacant), Stilt (parking & reception), Ground floor, 1st, 2nd & 3rd floor each having 06 guest rooms (total 24 guest rooms).
3. Type of Occupancy : Residential (Guest House)
4. Type of Case : New Case
5. Details of Previous FSC letter : NBC/ UBBL- 2016
6. Fire Safety direction letter No. : N/A
7. Date of Inspection : 10.09.2026
8. Name of the Inspecting officers : ADO R.K. Yadav (DWK)
9. Name and designation of officer from the building side : Manager
10. Year of construction : 2015 (As per online application)
11. Applicant's letter No : ID No. 2026081910561 dated 20.08.2026

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	Requirements per UBBL/NBC-2016	Provided at Site	Remarks MR/NMR
1	**Access to Building.**			
	• Road width	6.0 m	6.0 m	MR
	• Gate width	N/A	Directly accessible from road	N/A
	• Width of internal road	N/A	N/A	N/A
2	**Number, Width, Type and Arrangement of Exits.**			
	a. Number of Staircases			
	• Upper floor	02 Nos.	02 Nos.	MR
	• Basement	02 Nos.	02 Nos.	MR
	B. Width of Staircases			
	• Upper floor	1.50 m each	1.50 m each	MR
	• Basement	1.50 m each	1.50 m each	MR
	c. Protection of Exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	N/A	N/A	N/A
	d. No. of Continuous Staircases to Terrace	02 nos.	Provided	MR
	e. Width of Corridor	1.80 m	Provided	MR
	f. Door Size	1.0 m	Provided	MR
3	**Compartmentation.**			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Sealed	MR
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers	N/A	N/A	N/A
4	**Smoke Management System.**			
	• Basement	12 ACPH	Provided	MR
	• Upper floor	12 ACPH	Natural Ventilation	MR
5.	**Fire Extinguishers.**			
	• Total numbers	15 nos.	Provided	MR
	• Types	ABC /CO_2	Provided	MR
	• IS marking	ISI marked	Provided	MR
06	**First-Aid-Hose Reels.**			

N/A

	• Total numbers on each floor	01 Nos.	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	05 mm	Provided	MR
07	**Automatic Fire Detection, CO detection and Alarming System.**			
	• CO Type of detectors	Required	Provided	MR
	• Location of main panel	Required	At Stilt	MR
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	Required	Provided	MR
	• Hooter's location	Each floor	Provided	MR
08	**MOEFA**	Required	Provided	MR
09	**Public Address System.**	N/A	N/A	N/A
10	**Automatic Sprinkler System.**			
	• Basement & Stilt	Required	Provided	MR
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	**Internal Hydrants**			
	• size of riser/down-comer	N/A	100 mm	N/A
	• Number of hydrants per floor	N/A	01 nos.	N/A
	• Hose box	N/A	Provided	N/A
12	**Yard Hydrants.**			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
13	**Pumping Arrangements.**			
	➢ Ground Level			
	• Discharge of main pump			
	• Head of main pump	N/A	N/A	N/A
	• Number of main pumps	N/A	N/A	N/A
	• Jockey pump out put	N/A	N/A	N/A
	• Jockey pump head	N/A	N/A	N/A
	• Standby pump out put	N/A	N/A	N/A
	• Standby pump head	N/A	N/A	N/A
	• Auto starting /manual stopping	N/A	N/A	N/A
	• Pump house access	N/A	N/A	N/A
	➢ Terrace Level			
	• Discharge of pump	450 LPM × 2	450 LPM × 2	MR
	• Head of the pump	40 m	40 m	MR
	• Power supply	Required	Provided	MR
	• Auto Starting of pump	Required	Provided	MR
14	**Captive Water Storage for Fire Fighting.**			
	• Underground tank capacity	N/A	N/A	N/A
	• Draw-off connection	N/A	N/A	N/A
	• Fire service inlet	N/A	N/A	N/A
	• Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	15,000 ltrs	Provided	MR
15	**Exit Signage.**	Required	Provided	MR

N/S

16	**Provision of Lifts.**			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	Required	Provided	MR
	• Firemen's grounding switch	Required	Provided	MR
	• Lift Signage	Required	Provided	MR
17	**Standby power supply**	Required	Provided	MR
18	**Refuge Area.**			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	**Fire Control Room**			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
	Special Fire Protection systems for protection of special Risks, if any:	Required	02 ABC type fire extinguishers provided near elect. Panel.	MR

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Note: - The building comprised of basement, stilt, ground plus three upper floors, using basement (vacant), stilt (parking & reception) ground floor, 1st, 2nd and 3rd floor each having 06 guest rooms respectively (total 24 guest rooms only).

Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the rules **it is recommended to grant Fire Safety Certificate** under Rule 35 of the Delhi Fire Service Rule 2010.

28/9/2026

Signature of Inspecting Officer
Name: - R.K. Yadav
Designation: - ADO (DWK)

DO (SW)

5/X/26

DFO (SW)

CFO (SW)

07/10/2026

Debabrata Mukherjee

7/X/26

A.K. MALIK

CFO to issue -

9/X/26

CFO (SW)

13/X/26

A.K. MALIK

By CDO(W) – on M/R

ADO(DWRS)

T-T letter is put up for sign. please

R.R. Yadav
21.09.2026

CFO

21/9/26
A.K. MALIK

M.S. cell

Deemed Approved
21/09/26

Debabrata Mukherjee