



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI

No. F6/DFS/MS/SZ/2026/ 248

Dated: 18/06/2026

To,

The Commissioner MCD,
Civic Centre, Minto Road,
New Delhi- 110002.

Sub: Regarding issuance of FSC from fire safety point of view in respect of Plot No. E-14,
Hauz Khas Enclave, New Delhi.

Sir,

Please refer to online applications vide ID No. 10118754 dated- 04/06/2026. In this connection, it is to inform you that the building/premises was inspected by the officers concerned of this department DO(SD), ADO(BCP) on 09/06/2026 with Sh. Parveen Kumar JE(Bldg.) MCD & Sh. Manoj Kumar AE(Bldg.) MCD. During the inspection the following shortcomings were observed.

1. Fire check doors are not provided in the basement at staircase for compartmentation.
2. Smoke management is not provided in the basement.
3. Lift lobby is not provided in the basement.
4. Fireman switch is not provided in the lift.
5. Exit signage's are not provided.

In view of above, the Fire Safety Certificate cannot be issued at this stage & case is rejected.

Yours faithfully,


A. K. Malik
Chief Fire Officer



Copy To: -

1. The Owner/occupier, M/s Plot No. E-14, Hauz Khas Enclave, New Delhi. (Online applications vide ID No. 10118754 dated-04/06/2026)