



Dated: 15/04/2025

F6/DFS/MS/School/NDZ/2025/ 487

FIRE SAFETY CERTIFICATE

Certified that **Eastern Delhi Public School at Village Khichripur, Opp. 10 Block, Khichripur Colony, Delhi-91**, comprised of **Basement, Ground plus two upper floors only (School running at Ground plus two upper floors only)** owned/ occupied by **Eastern Delhi Public School**, was issued Fire Safety Certificate by this department vide letter No. F6/MS/DFS/2006/1510 dated 06/07/2006. The school building was re-inspected by the officer concerned of this department on 01/04/2025 in presence of Mr. Jagat Singh (Manager) of the school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with Circular No. 262 - 362 dated 17/01/2005 and the school is fit for occupancy class **"Educational Building" (Group - B)**, **affidavit dated 26.03.2025 regarding school running at Ground plus two upper floors only & basement is used for storage purpose only** (with effect from 15/04/2025 for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS Rules, 2010. Subject to conditions, printed below.

Issued on 15/04/2025 at New Delhi by.

(ATUL GARG)
DIRECTOR

OK (u) DELHI FIRE SERVICE

Copy to: -

1. The Dy. Director of Education, B - Block, Yamuna Vihar, Delhi - 110053.
2. The Principal, Eastern Delhi Public School at Village Khichripur, Opp. 10 Block, Khichripur Colony, Delhi-91.

Conditions for the validity of Fire Safety Certificate

1. **This fire safety certificate is valid for Ground plus two upper floors only.**
2. **At the time of inspection basement is being used for storage purpose only.**
3. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry
4. All the means of escape shall be kept free of all the type of obstruction all the time.
5. All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
6. All the firefighting equipment's shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
7. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc. may be got verified from the authorities concerned.
8. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
9. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1	Name & address of the building	Eastern Delhi Public School at Village Khichripur, Opp. 10 Block, Khichripur Colony, Delhi-91.				
2	Building is comprised of	Basement, Ground plus two upper floors only (School running at Ground plus two upper floors only, affidavit enclosed)				
3	Type of occupancy	Educational Building				
4	Type of case	Renewal				
5	Details of previous FSC	F6/MS/DFS/2006/1510 dated 06/07/2006				
6	Fire safety directives letter no.	Circular No. 262 - 362 dated 17/01/2005				
7	Date of inspection	01/03/2025				
8	Name of the inspecting officers	Yashwant Singh Meena, A.D.O / Laxmi Nagar				
9	Name of the designation of officer from the building side	Mr. Jagat Singh (Manager)				
10	Year of construction	1999				
11	Applicant's letter no.	Outdoor Diary No. 15022 dated 26/03/2025				
S. No	Minimum standard of fire prevention and fire safety U/R 33	Circular Requirement	Provided at site	Remarks MR/NMR		
1.	Access to Building:					
	A	Road width	6.0 mtrs.	6.0 mtrs.	MR	
	B	Gate width	N/A	N/A	N/A	
	C	Width of internal road	N/A	N/A	N/A	
2.	Number, Width, Type and Arrangement of Exits:					
	A	Number of staircases				
		a	Upper floor	1 nos.	1 nos.	MR
		b	Basement	1 nos.	1 nos.	MR
	B	Width of staircases				
		a	Upper floor	1.5 m	1.56 m	MR
		b	Basement	1.5 m	1.27 m	MR (Old case)
	C	Protection of exits				
		a	Fire check door	N/A	N/A	N/A
		b	Pressurization	N/A	N/A	N/A
	D	No. of continuous staircases to terrace	1 no.	1 no.	MR	
	E	Width of corridor	1.5 m	1.5 m	MR	
	F	Door size	1.0 mtr.	1.0 mtr.	MR	
3.	Compartmentation:					
	A	Fire check door	NA	NA	NA	
	B	Sealing of electrical shafts	N/A	N/A	N/A	
	C	Fire rating of shaft door	N/A	N/A	N/A	
	D	Water curtain	N/A	N/A	N/A	
	E	Fire dampers	N/A	N/A	N/A	
4.	Smoke Management System:					
	A	Basement	N/A	N/A	N/A	
	B	Upper floor	N/A	N/A	N/A	


W

Shaheed Rajpal DAV Public School located at Dayanagar, Delhi					
5.	Fire Extinguisher:				
	A	Total numbers	10 nos.	10 nos.	MR
	B	Types	CO ₂ & ABC	CO ₂ & ABC	MR
	C	ISI marking	ISI Marked	ISI Marked	MR
6	First-Aid-Hose Reel:				
	A	Total numbers of each floor	1 nos.	1 nos.	MR
	B	Length of hose reel hose	30 m	30 m	MR
	C	Nozzle diameter	05 mm	05 mm	MR
7	Automatic Fire Detection and Alarming System:				
	A	Type of detectors	N/A	N/A	N/A
	B	Location of main panel	N/A	N/A	N/A
	C	Location of repeater panel	N/A	N/A	N/A
	D	Alternate source of power	N/A	N/A	N/A
	E	Hooters	N/A	N/A	N/A
8	MOEFA:		N/A	N/A	N/A
9	Public Address System:		N/A	N/A	N/A
10	Automatic Sprinkler System:				
	A	Basement	N/A	N/A	N/A
	B	Upper floor	N/A	N/A	N/A
	C	Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants:				
	A	Size of riser/down-comer	N/A	N/A	N/A
	B	Number of hydrants per floor	N/A	N/A	N/A
	C	Hose box	N/A	N/A	N/A
12	Yard Hydrants:				
	A	Total number of hydrants	N/A	N/A	N/A
	B	Hose box	N/A	N/A	N/A
13	Pumping Arrangements:				
1	Ground level				
	A	Discharge of main pump	N/A	N/A	N/A
	B	Head of main pump	N/A	N/A	N/A
	C	Number of main pumps	N/A	N/A	N/A
	D	Jockey pump out put	N/A	N/A	N/A
	E	Jockey pump head	N/A	N/A	N/A
	F	Standby pump out put	N/A	N/A	N/A
	G	Standby pump head	N/A	N/A	N/A
	H	Auto starting /manual stopping	N/A	N/A	N/A
	I	Pump house access	N/A	N/A	N/A
2	Terrace Level				
	A	Discharge of pump	220 LPM	220 LPM	MR
	B	Head of the pump	40 m	40 m	MR
	C	Power supply	Required	Provided	MR
	D	Auto starting of pump	Required	Provided	MR

14	Captive Water Storage for Fire Fighting:			
	A	Underground tank capacity	N/A	N/A
	B	Draw-off connection	N/A	N/A
	C	Fire service inlet	N/A	N/A
	D	Access to tank	N/A	N/A
	E	Overhead tank capacity	2,500 ltr.	2500 ltr.
15	Exit Signage:		Required	Provided
16	Provision of Lifts:			
	A	Pressurization of lift shaft	N/A	N/A
	B	Pressurization of lift lobby	N/A	N/A
	C	Communication in lift car	N/A	N/A
	D	Firemen's grounding switch	N/A	N/A
	E	Lift signage	N/A	N/A
17	Standby Power Supply:		N/A	N/A
18	Refuge Area:			
	A	Total area	N/A	N/A
	B	Location	N/A	N/A
19	Fire Control Room:			
	A	Detector system panel	N/A	N/A
	B	Flow switch panel	N/A	N/A
	C	PA system panel	N/A	N/A
	D	Battery backup	N/A	N/A
	E	Building floor plans	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:		N/A	N/A

The fire protection system was randomly checked and tested and was found functional at the time of inspection.

Keeping in view of the deemed compliance of minimum standards on fire prevention and fire safety measures as required under the Rules the Fire Safety Certificate issued vide letter no. F6/MS/DFS/2006/1510 dated 06/07/2006 Renewal under rule 35(6) of the Delhi Fire Rules 2010 is recommended.


3/4/2025

Signature of the Inspecting Officer
Name: - Yashwant Singh Meena
Designation: - ADO (L.N)

D.O./East

Dy. C.F.O. (N.B.Z.)

C.F.O.

DIRECTOR

Approval
3/4/2025

Kirp
04/04/25

8/4/2025

ADP/LN