



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आजादी का
अमृत महोत्सव

No. F6/DFS/MS/EH/2025/ 178

Dated: 09/05/2025

FIRE SAFETY CERTIFICATE

Certified that the Eating House in the name & style of Karigari (A Unit of Karigari Delicacies LLP) located at Shop No. 01, Ground Floor, Infinity SK Mall, Karkardooma Pink Line Metro Station Gate No. 03, Delhi- 110092, in a building comprised of ground & 02 upper floors owner/occupied by M/s. Karigari (A Unit of Karigari Delicacies LLP) have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules- 2010 and verify by the officer concerned of Delhi Fire Service on 29.04.2025 in the presence of Sh. Sunder (Manager) and that the premises is fit for occupancy class **Group D "Assembly (Restaurant)" at Ground Floor only** and valid up to 31.03.2028 in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules- 2010.

Issued on 09/05/2025 at New Delhi by.

(Atul Garg)
Director

Delhi Fire Service

Copy to: -

1. The Commissioner, Municipal Corporation of Delhi, with a request to ensure the occupancy detailed above.
2. Online ID No.- 2025041006087 dated 11.04.2025
3. The Manager, Karigari (A Unit of Karigari Delicacies LLP), Shop No. 01, Ground Floor, Infinity SK Mall, Karkardooma Pink Line Metro Station Gate No. 03, Delhi- 110092.

Following fire safety directives must be adhered to:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate through MCD Portal along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT				
1	Name & Address of the Building		M/s Karigari (A Unit of Karigari Delicacies LLP) at Shop No-1, Ground Floor, Infinity SK Mall Karkardooma Pink Line Metro Station Gate No-3, Delhi 110092.	
2	Type of Occupancy		Restaurant at Ground Floor only	
3	Building Comprised of		Ground & 02 Upper Floors	
4	Type of Case		New Case	
5	Details of Previous NOC		Nil	
6	Fire Safety Directives Letter No		F6/DFS/MS/BP/2004/194 dated 14/06/2024	
7	Date of Inspection		29/04/2025	
8	Name of the Inspecting Officers		DO (East) & ADO (RN)	
9	Name & Designation of Officers from the building side		Mr. Sunder (Manager)	
10	Year of construction		2024	
11	Applicant letter online ID.		MHA Portal ID No- 2025041006087 dated 11/04/2024	
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Directive Requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.	Building FSC F6/DFS/MS/Metro/2025/NDZ/169 dated 07/04/2025		
	• Road width	7.50 mtr	Provided	MR
	• Gate width	4.50 mtr	Provided	MR
	• Width of internal road	06 mtr	Provided	MR
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase	Provided and maintained by DMRC/Infinity Mall		
	➤ Upper floors.	NA	Provided	NA
	➤ Basement floor.	NA	Provided	NA
	b) Width of Staircase	Ground floor only		
	➤ Upper floors	NA	NA	NA
	➤ Basement floor	NA	NA	NA
	c) Protection of exits			
	➤ Fire check door	Required	Provided	MR
	➤ Pressurization	NA	NA	NA
	d) No. of continuous staircase to terrace	NA	Provided	NA
	e) Width of corridor	NA	Provided	NA
	f) Door size	02mtr each	02 mtr each & 01m	MR
3	Compartmentation.			
	• Fire check door.	Required	Provided	MR
	• Sealing of electrical shafts.	Required	Provided	MR
	• Fire rating of shaft door.	02 hrs	Provided	MR
	• Water curtain	N/A	N/A	N/A
	• Fire dampers.	N/A	Provided	N/A
4	Smoke Management system.			
	• Basement	N/A	N/A	N/A
	• Upper floors /Ground floor	Required	Provided	MR
5	Fire Extinguishers.			
	• Total numbers	ISI marked	05 Nos	MR
	• Types		W. CO ₂ , DCP & CO ₂	MR
	• ISI Marking		Provided	MR
6	First Aid Hose Reels.			
	• Total numbers on each floor.	Near restaurant	Provided	MR
	• Length of hose-reel hose.		Provided	MR
	• Nozzle Diameter		Provided	MR
7	Automatic fire detection & alarming system.			
	• Type of detectors	Required	Provided	MR
	• Location of Main Panel	Required	Provided	MR
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	Required	Provided	MR
	• Hooter's location	All floor	Provided	MR

8	MOEFA	Required	Provided	MR
9	Public Address System	Required	Provided	MR
10	Automatic Sprinkler System	Provided and maintained by DMRC/Infinity Mall		
		N/A	N/A	N/A
	<ul style="list-style-type: none"> Basement Upper floors Sprinkler above false ceiling 	Required	Provided	MR
		N/A	N/A	N/A
11	Internal Hydrants.	Provided and maintained by DMRC/Infinity Mall		
		N/A	Provided	N/A
	<ul style="list-style-type: none"> Size of Riser/Down-comer Number of Hydrant per floor Hose box. 	N/A	Provided	N/A
		N/A	Provided	N/A
12	Yard Hydrants.	Provided and maintained by DMRC/Infinity Mall		
	<ul style="list-style-type: none"> Total number of hydrants. Hose box. 	N/A	Provided	N/A
		N/A	Provided	N/A
13	Pumping arrangements.	Provided and maintained by DMRC/Infinity Mall		
	<ul style="list-style-type: none"> Ground Level 	Provided and maintained by DMRC/Infinity Mall		
	<ul style="list-style-type: none"> Discharge of main pump. Head of main pump. Number of main pumps. Jockey Pump output. Jockey Pump head. Standby Pump output. Standby Pump head. Auto Starting/Manual Stopping. Pump house access. 	N/A	2850 LPM	N/A
		N/A	60m	N/A
		N/A	01	N/A
		N/A	180 LPM	N/A
		N/A	70m	N/A
		N/A	2850 LPM	N/A
		N/A	60m	N/A
		N/A	Provided	N/A
		N/A	Provided	N/A
	<ul style="list-style-type: none"> Terrace Level 			
	<ul style="list-style-type: none"> Discharge of pump. Head of pump. Power supply. Auto starting of pump. 	450 LPM	Provided	MR
		40m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive water storage for fire fighting.	Provided and maintained by DMRC/Infinity Mall		
	<ul style="list-style-type: none"> Underground tank capacity. Draw-off connection. Fire Service Inlet. Access to tank. Overhead tank capacity. 	N/A	2,00,000 Ltrs	MR
		N/A	Provided	MR
		N/A	Provided	MR
		N/A	Provided	MR
		N/A	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.	Provided and maintained by DMRC/Infinity Mall		
	<ul style="list-style-type: none"> Pressurization of lift shaft. Pressurization of lift lobby. Communication in lift car. Fireman's switch. Lift signage. 	N/A	N/A	N/A
		N/A	N/A	N/A
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
17	Standby Power Supply	Required	Provided	MR
18	Refuge Area			
	<ul style="list-style-type: none"> Total area Location 	N/A	N/A	N/A
		N/A	N/A	N/A
19	Fire Control Room.	Provided and maintained by DMRC/Infinity Mall		
	<ul style="list-style-type: none"> Detector system panel. Flow switch panel. PA system panel. Battery backup. Building floor plan. 	Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
20	Special Fire Protection System for the Protection of special Risk, if any.	Required	Provided	MR
		Required	Provided	MR

The Fire protection systems provided in the building were test checked at random and found functional at the time of inspection.

Keeping in view of the substantially satisfactory compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, it is recommended to issue Fire Safety Certificate under rule 35 (3) of the Delhi Fire Service Rules, 2010

Approved
01/05/2015

Signature of the inspection Officer
Name :- A.K. Jaiswal
Designation:- DO/East

Chief
01/05/2015

Signature of the Inspecting Officer
Name :- C.L. Meena
Designation:- ADO/RN

By C.F.O. (NDZ)

05/05/25

C.F.O.
7/5/2015
Director
11/5/2015

ADY RW

*Sir F.T is put up for your kind perusal & signature
p/s:-1*

Director
8/5/2015

ADP
08/05/2015
ADo (MR)

Mr
Uplandel
09/05/25
D