GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/School/NDZ/2025/ 218

Dated: 15 /04/2025

To

The Principal, Ekta Public School, B-341-397-404-341A, Gali No.-6, Nehru Vihar, Dayalpur, Delhi-110094.

Sub: Regarding Fire Safety Certificate in r/o Ekta Public School, B-341-397-404-341A, Gali No.-6, Nehru Vihar, Dayalpur, Delhi-110094.

Sir,

This has reference to your letter No. EPS/25 dated 06/02/2025 on the subject cited above. In this regard, it is to inform you that the premises was inspected by the officer concerned of this department on 17/03/2025 in the presence of Mr. Ghan Shyam Panday (Manager) to ascertain the availability and operability of the fire prevention and fire safety measures and observed that at present building comprised of **Ground Floor**, 1st Floor & 2nd Floor only.

Following shortcomings were observed during the inspection: -

- There are two building connected to each other at 2nd floor only. They are required to be connected
 at 1st floor also or one more staircase is to provided in both buildings to meet the requirement.
- 2. Hose reel hose is provided but non-functional.
- 3. Fire Pump of capacity 450LPM is provided but non-functional.
- 4. Overhead tank capacity of 1,000 ltr is provided against requirement of 10,000 ltr.

5. Exit signage found removed.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected under sub rule (3) of Rule 37 of DFS Rules-2010. The occupancy of the building/premises in absence of requisite fire safety arrangement shall be at the risk and liability of the management. The Statutory Authority may take suitable necessary action as deemed fit.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above snortcomings. The web links for DFS Act-2007 / Rules 2010 & Form "J" are as under: http://www.delhi.gov.in/wps wcm/connect/doit_fire/Fire/Home/Forms

Yours faithfully

ATUL GARG)

DELHI FIRE SERVICE

Anla

Copy to:-

The Dy. Director of Education, B-Block, Yamuna Vihar, Delhi-110053.