

c1135



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7/5
आज़ादी का
अमृत महोत्सव

No. F6/DFS/MS/GH/NDZ/2025/ 192

Dated: 22/04/2025

To

The Joint Commissioner of Police (Licensing),
1st Floor, Police Station Defence Colony,
New Delhi.

Ref: elt.mcdonline application no. 2025040405577

Sub: Regarding renewal of Fire Safety Certificate in respect of **M/s Elegance Guest House**
located at **7885/34, Arakashan Road, Pahar Ganj, New Delhi.**

Sir,

With reference to the elt.mcdonline application no. 2025040405577 on the subject cited above, it is informed that the said guest house was inspected by the officer concerned of this department on. 12.04.2025 in the presence of Mr. Vijay Kumar Mishra (Manager) and it was observed that the building is comprised of **Basement + Ground + 03 upper floors + Temporary construction on terrace.** During the inspection following shortcomings were observed:-

1. Temporary construction on terrace shall be removed.
2. No ventilation provision in common area & basement.
3. Fire Check Door found removed at all floors.
4. Fire pump having capacity of 900 LPM and head 30 meters has not been provided.
5. Overhead tank capacity of 10,000 litres has not been provided.
6. Auto start mechanism of fire pump was found removed.

In view of above shortcomings, the application for renewal of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)

Director
Delhi Fire Service

HA