

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI – 110001


No. F6/DFS/MS/EH/WZ/2026/70

Dated: 23/01/2026

FIRE SAFETY CERTIFICATE

Certified that the M/s Eleven Course (A Unit of Eleven Course Vimbri Hospitality LLP) located at Property No. 21/31, Third Floor, Mall Road, Timarpur, Delhi – 110054 comprised of **Basement, Ground & 03 upper floor**. The premises was inspected by the officer concerned of this department on 31/12/2025 in the presence of **Mr. Shivam Gupta, Owner** and found that the said restaurant premises has complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **-Assembly (Group D) for Restaurant at third floor only**, with effect from:23/01/2026.....for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued -23/01/2026-----at New Delhi by.


 (S. K. Dua)
 14/01/26

Dy. Chief Fire Officer

Copy to: -

1. The Commissioner, MCD, Civic Centre, New Delhi.: Online ID – 2025122015942 Dt. 22/12/2025.
2. The Manager, M/s Eleven Course (A Unit of Eleven Course Vimbri Hospitality LLP), Property No. 21/31, Third Floor, Mall Road, Timarpur, Delhi – 110054.

Conditions for the validity of Fire Safety Certificate

1. **This FSC is valid for eating house / restaurant at third floor only.**
2. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
3. Any loss of life or property due to nonfunctional fire safety measures shall be at the responsibility of the management.
4. The trained firefighting staff should be available round the clock.
5. Any deviation w.r.t. construction, electric installation, set back area etc. shall be verified by the concerned building sanctioning authority.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six months prior to its expiry.
10. Any flammable material for interior decoration is prohibited.

INSPECTION REPORT					
1.	Name & address of the building	Eleven Course (A Unit of Eleven Course Vimbri Hospitality LLP) located at 21/31, Third Floor, Mall Road, Timarpur, Delhi – 110054.			
2.	Building Comprised of	Basement, Ground & 03 upper floor but Restaurant is running at 3rd floor only			
3.	Type of Occupancy	Assembly/Restaurant			
4.	Type of Case	New case			
5.	Details of previous NOC No.	N/A			
6.	Fire Safety directives Letter No.	NBC Part-IV			
7.	Date of inspection	06/01/2026			
8.	Name of the Inspecting Officer	Sh. Kaushal Kishore, ADO (SJ)			
9.	Name and designation of Officer from the building side	Sh. Shivam Gupta (Owner)			
10.	Year of Construction	2020			
11.	Applicant's letter No./Online Appl.	Online MHA Portal ID. No- 2025122015942 Dt. 22/12/2025			
S. No.	Minimum standards on fire prevention and fire safety U/R 33	Requirements UBBL/NBC	Provided at site	Remarks MR/NMR	
1.	Access of building				
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	09 mtr N/A N/A	12 mtr approx. N/A N/A	MR N/A N/A	
2.	Number, width, Type & Arrangements of exits				
	a. Number of staircases <ul style="list-style-type: none"> Upper floors Basements b. Width of staircases <ul style="list-style-type: none"> Upper floors (Two exit) Basements c. Protection of exits <ul style="list-style-type: none"> Fire check door Pressurization d. No of continuous staircase to terrace e. Width of Corridor f. Door Size	02 N/A	02 02m & 1.50m 02m & 1.50m Required N/A	MR N/A N/A MR N/A N/A	
3.	Compartmentation				
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	Required N/A N/A N/A N/A	Provided N/A N/A N/A N/A	MR N/A N/A N/A N/A	
4.	Smoke Managements System				
	<ul style="list-style-type: none"> Basement. Upper floors 	N/A Required	N/A Exhaust Fan installed	N/A MR	
5.	Fire Extinguishers				
	<ul style="list-style-type: none"> Total numbers Types ISI marking 	06 nos. ABC/ CO ₂ Required	08 nos. ABC-5, CO ₂ -3 Provided	MR MR MR	
6.	First-Aid Hose Reels				
	<ul style="list-style-type: none"> Total numbers of each floor Length of hose reel hose Nozzle diameter 	01 30 m 05 mm	01 30 m 05 mm	MR MR MR	

7.	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detector (Smoke & heat) • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	Required	Provided	MR
		Third Floor	Provided	MR
		N/A	N/A	N/A
		Required	Provided	MR
		Third Floor	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basements • Upper Floor • Sprinkler above false ceiling 	N/A	N/A	N/A
		Required	Provided	MR
		N/A	N/A	N/A
11.	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	100 mm	100 mm	MR
		01	01	MR
		01	01	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	N/A	N/A	N/A
		N/A	N/A	N/A
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> • Ground Level ➢ Discharge of main pump ➢ Head of main pump ➢ Number of main pumps ➢ Jockey pump out put ➢ Jockey pump head ➢ Standby Pump out put ➢ Standby Pump Head ➢ Auto Staring/Manual stopping ➢ Pump House Access 	2280 LPM	2280 LPM	MR
		80 m	80 m	MR
		01 Nos	01 Nos	MR
		180 LPM	180 LPM	MR
		60 m	60mtr.	MR
		2280 LPM	2280 LPM	MR
		60 m	60 m	MR
		Required	Provided	MR
		Required	Provided	MR
	<ul style="list-style-type: none"> • Terrace level ➢ Discharge of pump ➢ Head of the pump ➢ Power supply ➢ Auto starting of pump 	450 LPM	Provided	MR
		40m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive water storage for firefighting			
	<ul style="list-style-type: none"> • Underground tank capacity ➢ Draw of connection ➢ Fire service inlet ➢ Access to tank • Overhead Tank capacity 	1,00,000 Liters.	1,00,000 Liters	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		10,000 Liters.	10,000 Liters.	MR
15.	Exit signage	Required	Provided	MR
16.	Provision of lifts			
	<ul style="list-style-type: none"> ➢ Pressurization of Lift Shaft ➢ Pressurization of lift lobby ➢ Communication in lift Car ➢ Fireman's Grounding Switch ➢ Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge area			
	<ul style="list-style-type: none"> ➢ Total area ➢ Location 	N/A	N/A	N/A
		N/A	N/A	N/A
19.	Fire Control Room			

N/A

	➤ Detector system panel ➤ Flow Switch Panel ➤ PA System Panel ➤ Battery backup ➤ Building Floor Plans	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
20.	Special Fire Protection Systems for Protection of Special Risks, if any;			N/A

Note:-


Earlier, DFS had issued FSC to this premises as restaurant (Assembly Building) in the name of M/s One 8 Restaurant (A Unit of Hill Stone Café LLP), 3rd floor, Block H, Mall Road, Delhi-110054 vide letter No. F6/DFS/MS/EH/2024/73 dated 08/03/2024. Now this company has stopped his operation and left the premises. Now Eleven Course (A Unit of Eleven Course Vimbri Hospitality LLP) has taken over this premises on third floor and applied for FSC from this department as a new case.

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

Keeping in view of substantial compliance of the minimum standards of fire prevention and fire safety measures required under the rules, **it is recommended to Grant Fire Safety Certificate under Rule 35 of the Delhi Fire Service Rules, 2010.**

Accordingly, DFA is prepared and put up for kind perusal and signature please.

Signature of the Inspecting Officer



9/1/26

Name :- Sh. Kaushal Kishore
Designation : ADO (SJ)

~~DO/ARW Approval~~
12/01/26

~~Dy CFO (Co2)~~ ~~ARW~~
14/01/26

~~Pr. Director~~

~~Dy. CFO to DSCN~~

~~15/01/26~~

~~My. CFO (ARW)~~

~~F.T. please.~~

~~KRP~~
16/01/26

~~ADO (SJ)~~
~~ARW~~