



C19
सत्यमेव जयते

FORM 'H': FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[See sub-rule (1) of rule 35]

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001

No. F6/DFS/MS/School/2026/NDZ/ 67

Dated: 05/06/2026

FIRE SAFETY CERTIFICATE

Certified that the **Elite International School** located at **2nd Pusta, Sonia Vihar, Delhi-110094**, comprised of Ground plus three upper floors, owned/occupied Elite International School was issued FSC vide letter No. F6/DFS/MS/School/2023/NDZ/528 dated 03/08/2023 (G+1). The premises was re-inspected by the officer concerned of this department on 22/05/2026 in the presence Sh. Naveen Kumar (Manager) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have complied with rule 33 of Delhi Fire Service Rules 2010 and that the premises is fit for occupancy class "Educational" (Group-B) for G+3 with effect from 05/06/2026 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010 & also conditions printed below.

Issued on.....05/06/2026.....at New Delhi by.


5/6/26

(Dr. S. K. TOMAR)

CHIEF FIRE OFFICER
DELHI FIRE OFFICER

To,

1. The Manage, Elite International School at 2nd Pusta, Sonia Vihar, Delhi-110094
2. The Dy. Director of Education, B- Block, Yamuna Vihar, Delhi-110092

Conditions for the validity of Fire Safety Certificate:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the firefighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

1. Name & address of the building : **Elite International School, 2nd Pusta, Sonia Vihar, Delhi-110094.**
2. Building is comprised of : **Ground plus three upper floors Only.**
3. Type of Occupancy : **Educational,**
4. Type of Case : **Addition/Alteration**
5. Details of Previous NOC letter : **F6/DFS/MS/School/2023/NDZ/528 dated 03/08/2023 (for Ground plus one upper floor)**
6. Fire Safety directive letter No. : **NBC Part-IV**
7. Date of Inspection : **22/05/2026**
8. Name of the Inspecting officers : **Deepak Kumar (ADO TP)**
9. Name and designation of Officer from the building side : **Sh. Naveen Kumar (Manager)**
10. Year of Construction : **2014, 2018 & 2025**
11. Applicant's letter No/Email Id : **eliteschooldelhi@gmail.com dated: 05/05/2026**

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	NBC Part IV Requirement	Provided at Site	Remarks MR/NM R
01	Access to Building			
	• Road width	06 mtr.	06 mtr.	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper floor	02 no.	02 no.	MR
	• Basement	N/A	N/A	N/A
	B. Width of Staircases			
	• Upper floor	1.50 mtr	2.20 m & 1.50 mtr.	MR
	• Basement	N/A	N/A	N/A
	c. Protection of Exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of Continuous Staircases to terrace	01 no.	01 no.	MR
	e. Width of Corridor	1.50 mtr	1.93 mtr	MR
	f. Door Size	01 mtr.	01 mtr.	MR
03	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
05.	Fire Extinguishers			
	• Total numbers	09 nos.	14 nos.	MR
	• Types	ABC /CO ₂	ABC & CO ₂	MR
	• IS marking	ISI marked	Provided	MR

06	First-Aid-Hose Reels			
	Total numbers on each floor	01 no.	02 no.	MR
	• Length of hose reel hose	30 mtr	30 mtr	MR
	• Nozzle diameter	05 mm	05 mm	MR
07	Automatic Fire Detection and Alarming System.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter	N/A	N/A	N/A
08	MOEFA	N/A	N/A	N/A
09	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
13	Pumping Arrangements.			
	➤ Ground Level			
	• Discharge of main pump	N/A	N/A	N/A
	• Head of main pump	N/A	N/A	N/A
	• Number of main pumps	N/A	N/A	N/A
	• Jockey pump out put	N/A	N/A	N/A
	• Jockey pump head	N/A	N/A	N/A
	• Standby pump out put	N/A	N/A	N/A
	• Standby pump head	N/A	N/A	N/A
	• Auto starting /manual stopping	N/A	N/A	N/A
	• Pump house access	N/A	N/A	N/A
	➤ Terrace Level			
	• Discharge of pump	450 LPM	450 LPM	MR
	• Head of the pump	40 M	40 M	MR
	• Power supply	Required	Provided	MR
	• Auto starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	• Draw-off connection	N/A	N/A	N/A
	• Fire service inlet	N/A	N/A	N/A
	• Access to tank	Required	Provided	MR
	• Overhead tank capacity	10,000 ltrs	10,000 ltrs	MR
15	Exit Signage.	Required	Provided	MR

N/14

16	Provision of Lifts.			
	• Pressurization of lift shaft	N/A	N/A	N/A
	• Pressurization of lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift signage	N/A	N/A	N/A
17	Standby Power Supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if Any:	N/A	N/A	N/A

The fire protection systems provided in the building/premises were checked, tested at random and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety measures as required under the rule, Earlier, the FSC was issued vide Letter No. F6/DFS/MS/School/2023/NDZ/528 dated 03/08/2023 for ground plus one upper floor and undertaking was submitted by Manager of Elite International School that second floor will not be used for school purpose. **However, presently the school is running on ground plus three upper floors and meet the requirement. Accordingly, Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules, 2010 is recommended.**

Deepak
25/05/2026.
Signature of the Inspecting Officer
Name :- Deepak Kumar
Designation :- ADO (Tahirpur)

DO(ED)

CFO (NDZ)

25/5/26

Principal Director

CFO (NDZ)

26/5/26

ADO/TP

25/5/26