



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No. F6/DFS/MS/WZ/2025/ 556

Dated: 26/11/2025

To,

Mr. Piyush Gaur,
M/s Emaya (LSC),
Plot No.1, between Block No.BG-1 & BG-2,
Paschim Puri,
Delhi.

Sub: Renewal of FSC in r/o M/s Emaya (LSC) located at Plot No.1, between Block No.BG-1 & BG-2, Paschim Puri, Delhi.

Sir,

Kindly reference to letter received in this department through outdoor diary no. 3273 dated 30.06.2023 on the subject cited above. The premise was inspected by the concern nominated authority of this department on 11.11.2025, in presence of Mr. Piyush Gaur, Liaoning officer to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. Smoke management and pressurization system functional manually but not interlinked with detection and alarm systems in auto mode.
2. MOEFA and detection system is not functional.
3. All sprinkler isolation valves found closed.
4. Terrace Fire pump with capacity of 900 LPM provided but not functional.
5. Pumps in pump house provided but not in auto mode.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:
http://www.delhi.gov.in/wps/wcm/connect/doiit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doiit_fire/FIRE/Home/Forms

Yours faithfully

24/11/25
(S. K. Dua)

Dy. Chief Fire Officer (WZ)
Delhi Fire Service