

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/GH/NDZ/2025/43

Dated:- 23/01/2025

To,

The Manager
M/S EMPORIO DX Guest House, 33,
Municipal no. 7885/2, Arakashan Road,
Pahar Ganj, New Delhi.

Sub: Issuance of FSC (Fire Safety Certificate) in r/o EMPORIO DX Guest House, 33, located at Municipal no. 7885/2, Arakashan Road, Pahar Ganj, New Delhi.

Sir,

This has reference to on line ID No. 2024123018550 dated 30.12.24, on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 15/01/25 in the presence of Mr. Ribul Raya and following shortcomings were observed:

1. Pump found nonfunctional.
2. PA system found nonfunctional.
3. Stand by power supply found nonfunctional.

In view of above e, the case is rejected and Fire Safety Certificate (FSC) cannot be renewed at this stage due to above shortcomings. Therefore, you are requested to rectify/ clarify the above shortcomings and re-submit for further consideration in the matter.

Yours faithfully,

(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to:

1. The Commissioner , MCD , Civic center , New Delhi
2. Addl. Commissioner of Police (Lic), 1st floor, Defence Colony Police Station, New Delhi.