



C/77

75  
आज़ादी का  
अमृत महोत्सव

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI**

No. F6/DFS/MS/BNQT/SZ/2026/ 420

Dated: 05/05/2026

To,

The Commissioner MCD,  
Civic Centre, Minto Road,  
New Delhi- 110002.

Sub: Regarding renewal of FSC from fire safety point of view in r/o.M/s. Eswara Kamdhenu Restaurant Pvt. Ltd., located at Site 59/18 Entire Ground Floor R.D Marg, Kalkaji, New Delhi-110019.

Sir,

Please refer to your online application no. No.2026040104059 dated 06/04/2026, on the subject cited above. In this connection, it is to inform you that the premises was inspected by officer concerned of this department on 23/04/2026 in the presence of Sh. D N Joshi(Manager) and following shortcomings were observed.

1. First Aid Hose reel is provided but it is not functional.
2. MOEFA is provided but not functional.
3. Exit Signage's are found removed.

In view of above Shortcomings, the application for renewal of Fire safety Certificate is cannot considered at this stage & rejected. The occupancy of the building/premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier.

Yours faithfully,

(A.K. Malik)

Chief Fire Officer

Copy To: -

1. The Owner/occupier,M/s. Eswara Kamdhenu Restaurant Pvt. Ltd., located at Site 59/18 Entire Ground Floor R.D Marg, Kalkaji, New Delhi-110019. (Online application No. 2026040104059 dated 06/04/2026).