



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

2/68



No. F6/DFS/MS/EH/NDZ/2025/ 48

Dated: 31/01/2025

To,

The Joint Commissioner of Police (Lic.),  
1<sup>st</sup> floor, Police Station Defence Colony,  
New Delhi – 110024.

**Subject: - Regarding grant of Fire Safety Certificate in r/o M/s Eswara Kamadhenu Restaurant Pvt. Ltd. located at Deen Dayal Upadhyaya College, Sector - 3, Dwarka, Delhi - 110078.**

Sir,

This has a reference to MHA application No. 2023102517714 dated 16/01/2025, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officers concerned of this department on 23/01/2025 in the presence of Mr. Gagan Chand (Manager) and observed that building comprised of Residential/Utility BL - basement, ground plus six upper floors. (Canteen /Restaurant/ running on ground floor only)

**Following shortcomings were observed during time of inspection in the restaurant/Canteen:**

1. Door size of 1.40 meters & 1.68 meters is provided against the requirement of 1.50 meters & 2.0 meters.
2. Fire Check doors not provided in kitchen.
3. Fire Extinguishers found empty.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)

DIRECTOR

o/c DELHI FIRE SERVICE

Copy to:-

1. The Manager, M/s Eswara Kamadhenu Restaurant Pvt. Ltd. located at Deen Dayal Upadhyaya College, Sector -3, Dwarka, Delhi - 110078.