

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/BNQT/2025/SZ/ 29
To

Dated: ..18../...02../2025

The Addl. Commission of Police,
Lic/Branch, 1st Floor PS Defence Colony,
New Delhi 110049.

Sub: Regarding issuance of FSC in r/o M/s Euphoria Banquet at Plot No F-3, Udyog Nagar, Industrial Area, Rohtak Road, New Delhi 110041.

Sir,

This has reference to with **MHA Portal ID 2025010700238 dated 23/01/2025** on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officers concerned of this department on 13.02.2025 in the presence of Mr. Dhiraj Kumar (Maintance) to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. Staircase of basement found closed.
2. Access staircase of pump room has found closed with plastic sheets.
3. Smoke management system in basement not working. The fresh air Duct in basement found removed.
4. Pressurization system of staircases found removed.
5. Automatic Detection system not working.
6. Sprinkler system not working. Sprinkler system in basement need to be extended in left out area.
7. Fire Fighting pumps are not on auto mode.
8. Pressurization of lift lobbies found removed.
9. Electrical panel installed inside rear staircase need to be removed.
10. The side set back has been covered with PVC sheds and Rear set back area has also been temporary covered and are being using for seating area.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

14/2