

c/150



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/WZ/2025/ BNQT/46

Dated:- 20/03/2025

To,

The Dy. Health Officer,
 Municipal Corporation of Delhi,
 Civic Centre, Minto Road, New Delhi-110002.

Subj:- Regarding renewal of Fire Safety Certificate in respect of M/s. Euphoria Banquet Hall, located at Plot No. F-3, Udyog Nagar Industrial Area, Rohtak Road, New Delhi-110041.

Sir,

This has reference to online application received through MCD online portal vide ID-2025022002133 dated 20/02/2025 on the subject cited above. In this connection, it is to inform you that the said banquet hall building have been inspected by the officer concerned of this department on 10/03/2025 in the presence of Sh. Gopal Kumar (Director) & Sh. Hement Singh (Electrician) to check the compliance of shortcomings issued by this department vide letter no. F6/DFS/MS/BNQT/2025/SZ/29 dated 18/02/2025.

During the course of inspection, it has been observed that the Management has rectified some of the shortcomings the status is under:-

S. no.	Shortcomings	Status
1.	Staircase of basement found closed	Rectified
2.	Access staircase of pump room has found closed with plastic sheets	Rectified. And another access to pump room from basement is also provided
3.	Smoke management system in basement not working. The fresh air duct in basement found removed	Rectified
4.	Pressurization system of staircases found removed	Not rectified. (However, provisioning are under progress)
5.	Automatic detection system not working	Rectified
6.	Sprinkler system not working. Sprinkler system in basement need to be extended in left out area	Not rectified. (However, extended work of sprinkler system in left our area is in under progress)
7.	Fire fighting pumps are not on auto mode	Not rectified
8.	Pressurization of lift lobbies found removed	Not rectified
9.	Electrical panel installed inside rear staircase need to be removed	Not rectified
10.	The side set back has been covered with PVC sheds and rear set back area has also been temporary covered and are being using for seating area.	Not rectified

c/49

In view of the shortcomings, the application for renewal of Fire safety Certificate cannot be considered at this stage & rejected. The occupancy of the building/premises in absence of requisite fire safety measures shall be at the risk and liabilities of the owner/occupier.

Yours faithfully,


(Arul Garg)
Director

SC
19/03/25

Copy to :-

1. The Authorized Signatory, M/s. Euphoria Banquet, Plot No. F-3, Udyog Nagar Industrial Area, Rohtak Road, New Delhi-110041.