

c-60

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001


No.F6/DFS/MS/GH/NDZ/2025/ 532

Dated : 04.11.2025

FIRE SAFETY CERTIFICATE

Certified that the M/s Euro Inn Guest House located at 8306 to 8308, Gali No.5, Multani Dhanda, Pahar Ganj, New Delhi comprised of Ground + 04 Upper floors, Ground floor – reception + 03 guest rooms, 1st floor to 3rd floor (04 guest rooms at each floors), total 15 guest rooms. The FSC was earlier granted by this department vide letter No. F6/DFS/MS/GH/NDZ/2022/468 dated 11/10/22 for 15 guest rooms only. Now, the premises was re-inspected by the officer concerned of this department on 16/10/25 in the presence of Sh. Amit Pal (Manager), and found that owner/ occupier of the said guest house submitted an affidavit dated 22/10/2025 regarding not to use any floor above third floor for any purpose have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Residential, (Sub Division-A-1) as above Ground + 03 Upper floors, Ground floor (reception + 03 guest rooms), 1st floor to 3rd floor (04 guest rooms at each floors), total 15 guest rooms up to third floor only with effect from 04.11.25 for period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued 04.11.25 at New Delhi by.


(Dr. S. K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service

OC BP

Copy to: -

1. The Commissioner, MCD, Civic Centre, New Delhi: kindly to ensure the occupancy as detailed above.
2. The Manager, M/s Euro Inn Guest House 8306 to 8308, Gali No. 5, Multani Dhanda, Pahar Ganj, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.
9. Any flammable material for interior decoration is prohibited.

INSPECTION REPORT

1. Name & address of the building M/s Euro Inn Guest House, 8306 to 8308 Gali No.5, Multani Dhanda, Pahar Ganj, New Delhi.
2. Type of occupancy: - Residential, Sub Division-A-1
Gr. + 04 Upper floors (total 15 Guest rooms)
Ground floor – (reception + 03 guest rooms),
1st floor to 3rd floor (04 guest rooms at each floor)
4th and above not in use as per affidavit dated 22/10/2025 regarding not to use any floor above third floor for any purpose
3. Type of case: - Renewal
4. Details of previous FSC: - No. F6/DFS/MS/GH/NDZ/2022/468 dated 11/10/22.
5. Fire safety directives No.- N/A
6. Date of inspection: - 16/10/25.
7. Name of the inspecting officer: - Sh. Bhupender Prakash (ADO/CC)
8. Name & designation of officer
From the building side: - Sh. Amit Pal (Manager)
9. Year of construction: - 2009
10. Applicant's letter No: - Online id no. 2025092213636 dated 08/10/25.

Old Case

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement Existing	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	N/A	6 mtr.	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	01 Nos.	01 Nos.	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	80cms.	125 cms.	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	N/A	N/A	N/A
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	1 mtr.	1 mtr.	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	N/A	N/A	N/A
	2) Upper floor	Required	Provided Natural/ Exhaust fan	MR
5.	Fire Extinguishers			
	1) Total numbers	12 Nos.	12 Nos.	MR

	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	01	01	MR
	2) Length of hose reel hose	30 mtr.	30 mtr.	MR
	3) Nozzle diameter	05 mm	05 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors CO	Required	Provided	MR
	2) Location of main panel	Gr. floor	G. floor	MR
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	Required	Provided	MR
	5) Hooter's Location	Gr. floor	Provided	MR
8.	MOEFA	N/A	Provided	N/A
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	450LPM	450 LPM	MR
	b) Head of pump	30 mtr.	30 mtr.	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Underground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	5000 ltr.	5000 ltr.	MR
15.	Exit Signage.			
		Required	Provided	MR

N/22

M/s Euro Inn Guest House located at 8306 to 8308, Gali No.5, Multani Dhanda, Pahar Ganj, New Delhi

16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection systems provided in the guest house building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter no. F6/DFS/MS/GH/NDZ/2022/468 dated 11/10/22, renewal under rule 35 of the Delhi Fire Service rules 2010, is recommended for approval up to third floor only.

Signature of the Inspecting Officer

Name: - Bhupender Prakash
Designation: - ADO (CC)

DO(GD)

Dy (F&S) (NDZ)

Principal Director

Dy. CFS (NDZ)

Addl. Secy

F.I. pl.

Dy. CFS (NDZ)