



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आजादी का
अमृत महोत्सव
C-85

No. F.6/DFS/MS/EH/SZ/2026/ 61

Dated: 20/01/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
Civic Centre, Minto Road,
New Delhi - 110002.

Subject: - Regarding grant of Fire Safety Certificate in r/o M/s M/s Euro Star Hotel at A -2 7, Road No. 1, Mahipalpur Extn. Delhi - 110037.

Sir,


This has a reference to your MCD Application No. 2025122316005 dated 23/12/2025, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officers concerned of this department on 14/01/2026 in the presence of Mr. Harmeet Kaur (Owner) and observed that building comprised of Basement, Ground floor plus three upper floors

Following shortcomings were observed during time of inspection:

1. Fire Check door found removed in basement.
2. Exhaust fan found removed in upper floor and basement.
3. Frist Aid hose reel provided but found not functional.
4. Carbon Monoxide type detectors found removed in rooms.
5. Automatic fire detection & alarming system provided but found not functional.
6. Automatic sprinkler system provided but found not functional.
7. Terrace Pump provided but found not functional.
8. Overhead capacity of 5,000 liters provided against the requirement of 10,000 liters.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is **rejected**. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


A.K. Malik
Dy. Chief Fire Officer
Delhi Fire Service
o/c @