



e 29  
एन सी टी  
दिल्ली

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001

No. F.6/DFS/MS/School/2025/NDZ/621

Dated: 07/05/2025

**FIRE SAFETY CERTIFICATE**

Certified that Evergreen Public School running ground floor, first floor & second floor of the building comprised of basement, ground plus four upper floors only (Basement, 3<sup>rd</sup> & 4<sup>th</sup> floor sealed) located at 152, West Azad Nagar, Delhi, owned/occupied Evergreen Public School was issued FSC vide letter No. F.6/MS/DFS/2006/1458 dated 03/07/2006 (for G+2). The premises was re-inspected by the officer concerned of this department on dated 08/04/2025 in the presence of Mr. Sh. Parvesh Minocha, Manager and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with Circular No. 262-362 dated 17/01/2005 issued by the Director of Education and that the building/premises is fit for occupancy class 'Educational (Group-B)' (ground floor, first floor & 2<sup>nd</sup> floor) with effect from 07/05/2025 for a period of **three** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 & also conditions printed below.

Issued on 07/05/2025 at New Delhi by

(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

To:-

The Manger,  
Evergreen Public School at 152, West Azad Nagar, Delhi

Copy to:-

The Dy. Director of Education  
D-Block Anand Vihar, Delhi-110092

**Conditions for the validity of Fire Safety Certificate**

1. FSC is valid for ground floor, first floor & 2<sup>nd</sup> floor only. Basement, 3<sup>rd</sup> floor & 4<sup>th</sup> floor which is sealed may not be used for any purpose failing which FSC should be treated null and void.
2. All the means of escape shall be kept free of all type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
6. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)



**INSPECTION REPORT**

1. Name & address of the building : Evergreen Public School,  
152, West Azad Nagar, Delhi-110032
2. Building is comprised of : Basement, Ground plus four upper floors,  
school is running ground plus two upper floors  
(Basement, 3<sup>rd</sup> floor and 4<sup>th</sup> floor sealed)
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC letter : F.6/MS/DFS/2006/1458 dated 03/07/2006
6. Fire Safety direction letter No : Circular 262-362 Dated: 17/01/2005 issued by DoE
7. Date of Inspection : 08/04/2025
8. Name of the Inspecting officers : ADO (Shd.) Deepak Kumar
9. Name and designation of Officer  
from the building side : Sh. Parvesh Minocha
10. Year of Construction : 2005 & 2014
11. Applicant's letter No : EPS/KN/2025/2835 Dated-15/02/2025

Sr. No	Minimum Standards on fire prevention and fire safety U/R33	Circular Requirement	Provided at Site	Remarks MR/NMR
01	Access to building.			MR
	• Road width	06 mtr.	07 mtr.	N/A
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits.			MR
	a. Number of Staircases	2 nos.	02 nos.	N/A
	• Upper Floor	N/A	Sealed	
	• Basement			
	B. Width of Staircases	1.50mtr.	1.25 mtr& 1.20 mtr	MR
	• Upper Floor	N/A	Sealed	N/A
	• Basement			
	c. Protection of exits	N/A	N/A	N/A
	• Fire check door	N/A	N/A	N/A
	• Pressurization	1 nos.	1 nos.	MR
	d. No. of continuous staircases to terrace	1.50 mtr.	Provided	MR
	e. Width of Corridor	01 mtr.	01 mtr.	MR
	f. Door Size			
03	Compartmentation.	N/A	N/A	N/A
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
04	Smoke Management System.	N/A	N/A	N/A
	• Basement	N/A	N/A	N/A
	• Upper floor			
05.	Fire Extinguishers.	12 nos.	12 nos.	MR
	• Total numbers	ABC /CO <sub>2</sub>	ABC /CO <sub>2</sub>	MR
	• Types	ISI marked	ISI marked	MR
	• IS marking			

2

✱



06	First-aid-Hose Reels.			
	• Total numbers on each floor	01 nos.	01 nos.	MR
	• Length of hose reel hose	30 mtr.	30 mtr.	MR
	• Nozzle diameter	05 mm	05 mm	MR
07	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
08	MOEFA	N/A	Provided	N/A
09	Public address System.	N/A	Provided	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	Provided	MR
	• Number of hydrants per floor	N/A	Provided	MR
	• Hose Box	N/A	Provided	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	➤ Ground Level	N/A	N/A	N/A
	• Discharge of main Pump	N/A	N/A	N/A
	• Head of Main Pump	N/A	N/A	N/A
	• Number of main pumps	N/A	N/A	N/A
	• Jockey pump out put	N/A	N/A	N/A
	• Jockey pump head	N/A	N/A	N/A
	• Standby pump out put	N/A	N/A	N/A
	• Standby pump Head	N/A	N/A	N/A
	• Auto Starting /Manual stopping	N/A	N/A	N/A
	• Pump House Access	N/A	N/A	N/A
	➤ Terrace Level			
	• Discharge of pump	250 Lpm	450 lpm	MR
	• Head of the Pump	40 mtr.	40 mtr	MR
	• Power supply	Required	Provided	MR
	• Auto Starting of pump	Required	Required	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	• Draw-off connection	N/A	N/A	N/A
	• Fire service inlet	N/A	N/A	N/A
	• Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	2,500ltr.	5,000ltr.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A

2 X



17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

**Note:-** The Management has been submitted undertaking (attached at C/23), that the basement (by brick), 3<sup>rd</sup> floor and 4<sup>th</sup> floor sealed.

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection. The previous shortcomings issued vide letter no. F.6/DFS/MS/School/2019/1989 dated 03/04/2019 has been rectified

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under rule. The FSC issued vide letter no. F.6/MS/DFS/2006/1458 dated 03/07/2006 renewal under rule 35 of the Delhi Fire Service Rules, 2010 is recommended.

*Deepak* 03/04/2025  
Signature of the Inspecting Officer  
Name :- Deepak Kumar  
Designation :- A.D.O (Shd)

DO(ED) *Deepak*  
03/04/2025

Dy. C.F.O. (N2)

*Deepak*  
11/04/25

C.F.O.

*Deepak*  
21/04/2025

*Deepak*  
29/04/25

*Deepak*  
29/04/25

हस्ताक्षर  
कलियुक्ति  
उद्देश्य फ्लोर फ्लोर  
Sealed फ्लोर  
और उद्देश्य  
फ्लोर फ्लोर

महोदय, निवेदन है कि तृतीय ओर चतुर्थ  
तल स्तरों विद्यालय प्रबंधन ने सील किया है।  
क्योंकि विद्यालय प्रबंधन के अकसाट ~~क~~ धर्मों की संख्या  
कम है। तृतीय व चतुर्थ तल की Sealed photo संलग्न  
है श्रीमान जी। F.T. आपके दस्तावेज के लिए प्रस्तुत है।

*Deepak* 03/04/2025