



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

C-11



No: F.6/DFS/MS/EH/2025/WZ/243

Dated: 03/06/2025

To,

The Joint Commissioner of Police,
Licensing Unit, 1st Floor,
Police Station, Defence Colony,
New Delhi.

Sub: - Regarding issuance of Fire Safety Certificate in r/o M/s Eversub India Pvt. Ltd. located at Plot No. 24, Deep Complex, Central Market, Deep Cinema Road, Ashok Vihar, New Delhi- 110052.

Sir,

This has reference to online application received through MCD portal vide ID- 2025050307793, on the subject cited above. In this connection, it is to inform you that the above said assembly building was inspected by officer concerned of this department on 27/05/2025 in presence of Ms. Julie (Manager). Following shortcomings were observed at the time of inspection.

1. Only single staircase of 0.75 m width found provided for mezzanine floor against the requirement of two staircases of 1.5 m width each.
2. Only single door of width 1.05 m provided against the requirement of two doors of 1.5 m width each.
3. First aid hose reel not provided.
4. Internal hydrant not provided.
5. Terrace level pump of 450 lpm discharge capacity not provided.
6. Overhead tank of 20,000 ltrs water storage capacity exclusively for fire pump found not provided.
7. Exit signage's not provided.
8. Details provided on MCD portal are not matching with actual building.

In view of above, the application for issuance of Fire Safety Certificate is not considered at this stage & rejected. The occupancy of the building/ premises in absence of requisites fire safety measures shall be at the risk and liabilities of the owner/ occupier.

Yours Faithfully

(Virendra Singh)
Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The owner/ occupier, M/s Eversub India Pvt. Ltd. located at Plot No. 24, Deep Complex, Central Market, Deep Cinema Road, Ashok Vihar, Delhi-52.
2. MCD Portal ID No. 2025050307793.