

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001



No. F.6/DFS/MS/CGHS/2025/SZ/ 425

Dated: 27/08/2025

To

Sh. Pushpendar Kumar,
eeeld10@dda.org.in
Executive Engineer (E),
Delhi Development Authority,
Electrical Division-10, B2B,
Janakpuri, New Delhi-110058

Sub: Renewal of Fire Safety Certificate for the Integrated Complex of 273 Multistoried EWS Housing with Facility Building behind DDA Project office at Manglapuri, Dwarka (Site-IV), New Delhi.

Sir,

This has reference to your letter No. F10(25)/EE(E)/ELD-10/DDA/25-26/432 dated 05/07/2025 received in this department vide outdoor diary No. 3506 dated 08/07/2025 on the subject cited above. In this connection, it is to inform you that the premise was inspected by the officer concerned of this department on 26/07/2025 from fire safety point of view in the presence of Sh. Rajwant Kumar Kushwaha, AE (DDA). During course of inspection, the shortcomings observed are as below: -

1. Fire check door for protection of exits and compartmentation found damaged/removed at some places.
2. First-aid hose-reels hose system found non-functional and shut-off nozzle missing.
3. Internal hydrant system found non-functional and hose-boxes empty.
4. Main fire pump and standby pump found non-functional/under repair.
5. Lift signage found removed at some places.
6. Pressurization in lift shaft found non-functional.

In view of the above, renewal of fire safety certificate cannot be considered at this stage. You are advised to rectify the shortcomings mentioned above under intimation to this department for further action in the matter.

Yours faithfully,


(Virendra Singh)
Chief Fire Officer
Delhi Fire Service

