

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/DFS/MS/2025/SZ/ 374

Dated:- 11 /08 /2025

To

The Coronation (Elec. Electricity)  
National Seeds Corporation Limited,  
Seed Bhawan, Pusa Complex,  
New Delhi 110012.

**Sub:** - Regarding issuance of fire safety certificate in r/o M/s Farm Bhawan at 14-15, Nehru Place, New Delhi


Sir,

This has reference to with letter received through Email dated 19/06/2025 on the subject cited above. In this connection, it is to inform you that the above mentioned premise was visited by the officer concerned of this department on 15.07.2025 in the presence of Mr. Prem Kumar (Care taker) to verify the present status of fire safety measures installed in the building. The fire safety arrangements were tested / checked and found following observations:-

1. Door closing device at fire check doors not provided.
2. Overhead tank capacity 10,000 ltrs provided against the required capacity 20,000 ltrs.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully

  
(VIRENDRA SINGH)  
CHIEF FIRE OFFICER  
DELHI FIRE SERVICE

Copy to:-

1. The Executive Engineer (Building Department) MCD Jal Vihar, Lajpat Nagar, New Delhi 110024.