



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आज़ादी का
अमृत महोत्सव

No. F6/DFS/MS/WZ/BNQT/2026/684

Dated: 16 07/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
Civic Center, New Delhi – 110002.

Subject: - Regarding renewal of Fire Safety Certificate in r/o FFH Grand (A Unit of B.K Enterprises), located at A3, Chote, Lal Park, Main Najafgarh Road, Kirti Nagar, New Delhi-110015.

Sir,

This has a reference to online MCD Application No. 2026060608288 dated 06/06/2026, on the subject cited above. In this connection, it is submitted that the premises was inspected by the officer concerned of this department on 22/06/2026 in the presence of Mr. Manu Bhatiya to verify the present status of fire safety measures installed in the building. The fire safety arrangements were tested / checked and found following observation: -

1. One exit provided at rear side of the building found permanently closed.
2. One exit provided at rear side is passing through the kitchen.
3. Fire check door not provided in the kitchen.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is **rejected**. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


15/07/26

(S. K. Dua)

Chief Fire Officer
Delhi Fire Service

Copy to :

1. The Owner/Occupier, FFH Grand (A Unit of B.K Enterprises), A3, Chote, Lal Park, Main Najafgarh Road, Kirti Nagar, New Delhi-110015.