



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**



No.F6/DFS/MS/School/SZ/2025/262

Dated: 22/04/2025

To

The Chairman,  
First Step School,  
H- 164, Saurabh Vihar, Jaitpur,  
Badarpur, New Delhi.

**Sub:-** Regarding issuance of Fire Safety Certificate in r/o **First Step School** located at **H- 164, Saurabh Vihar, Jaitpur, Badarpur, New Delhi.**

Sir,

With reference to the letter bearing outdoor diary no. 15021 dated 26.03.2025 on the subject cited above, it is informed that the school building was inspected by Assistant Divisional Officer (M. Road) from this department on 09.04.2025 in the presence of Mr. Bhupendra Sharma (Owner) and it was observed that the building is comprised of Ground + 02 upper floors. During the inspection following shortcomings were observed:-

1. Two no. of staircases of width 1.50 meters each from Ground to terrace have not been provided.
2. First aid hose reels at every floor have not been provided.
3. Fire pump of 450 LPM with head 40 m has not been provided.
4. Overhand tank capacity of 10,000 liters for firefighting has not been provided.
5. Exit signage has not been provided.

In view of above shortcomings, the application for issuance of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)  
Director  
Delhi Fire Service

e/c [Signature]

**Copy to:-**

1. The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.