

c/26

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110 001

No. F.6/DFS/MS/WZ/EH/2025/ 125

Dated: 19/03/2025

To,

Mr. Vijayender Kandiyak,
House No.575 Radhika apartment, Pocket-1,
DDA Flats, Phase-II, Sector-14, Dwarka, N.S.I.T, Dwarka,
New Delhi-110078.

Sub: Renewal of FSC in r/o M/s Foodlink F & B Holdings India Pvt. Ltd. located at Exhibition Hall No.2, 2nd floor, Food Court Kitchen, Convention & Expo Centre, Dwarka, Sector-25, Delhi-110078.

Sir,

This is reference to online application no.2025022102243 dated 21.02.2025, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on **10.03.2025**, in presence of **Mr. Harshit Mittal** to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. Café is not matching with CAF application building plan provided.
2. Manually operated electric fire alarm not provided near to restaurant.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" /MCD Portal with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:

http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/htt
p://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

Yours faithfully


(Atul Garg)
DIRECTOR
Ph; 011-23414000

Copy To:-

1. MCD Portal Id- 2025022102243 dated 21.02.2025.