

C47

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE

No.F.6/DFS/MS/School/2025/SZ/ 866

Dated: 04/07/2025

FIRE SAFETY CERTIFICATE

Certified that the building of **Fouji Model School** located at F-8, Gali No. 80, Mahavir Enclave, Part- 3, New Delhi-110059, running at ground plus two upper floors in a building comprised of ground plus three upper floors, was issued Fire Safety Certificate by this department vide letter No. .6/DFS/MS/SZ/2022/School/461 dated 27.04.2022. The School building was re-inspected by the officer concerned of this department on dated 28.06.2025 in the presence of Sh. Ashish (Principal), and found that the school building have deemed complied the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building/premises (**ground plus two upper floors**) is fit for occupancy class "**Educational**" w.e.f. 04/07/2025 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on 04/07/2025 at New Delhi by.


(Atul Garg)
Director
Delhi Fire Service

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054
2. The Principal, Fouji Model School located at F-8, Gali No. 80, Mahavir Enclave, Part- 3, New Delhi-110059.

Conditions for the validity of fire safety certificate: -

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building : Fouji Model School at F-8, Gali No. 80, Mahavir Enclave Part- 3, New Delhi- 110059
2. Building Comprised of : G+3 floors, but school running at ground, 1st & 2nd floor only.
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC : F.6/DFS/MS/SZ/2022/School/461 dated 27.04.2022
6. Fire Safety directives letter No : N/A
7. Date of inspection : 28.06.2025
8. Name of Inspecting Officer : A.D.O. R.K.Yadav
9. Name and designation of officers
From the building side : Sh. Ashish, Principal
10. Year of Construction : 2006
11. Applicant's letter No. : FMS/5/25/10, dated 13.05.2025

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	Accessible 01 m N/A	09mtrs 01 m N/A	M/R MR N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper Floors Basements 	02 no.'s N/A	Provided N/A	M/R N/A
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floor Basements 	1.50 m/additional staircase of .75 m if less than 1.50 m N/A	1.57 & 0.93 m N/A	M/R, old case N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircases to terrace	Required	01 nos.	MR
		Required	Provided	MR
	e. Width of Corridor	1.0 m	Provided	MR
	f. Door Size			
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"> Basements Upper floors 	N/A Required	N/A Natural ventilation	N/A M/R
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types ISI marking 	06 no's ABC/CO ₂ type ISI marked	Provided Provided ISI marked	M/R M/R M/R
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	One 30 mtrs 5 mm	Provided Provided Provided	M/R M/R M/R

N14

Star
18.

7.	Automatic fire detection and alarming system			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basement	N/A	N/A	N/A
	• Ground Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/Manual Stopping	N/A	N/A	N/A
	• Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	450 LPM	Provided	M/R
	➤ Head of the pump	30 mtrs	Provided	M/R
	➤ Power Supply	Required	Provided	M/R
	➤ Auto Starting of pump	N/A	Provided	M/R
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	10,000 ltrs	Provided	M/R
15.	Exit Signage.	Required	Provided	M/R
16.	Provision of Lifts.			
	(No Lift)			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A


N/15

	Standby power supply	N/A	N/A	N/A
18.	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. The shortcomings issued by this department vide letter No. F.6/DFS/MS/School/2025/SZ/243 dated 17.04.2025 have been rectified.

Note: - As per undertaking given by Principal of the school (placed at C-42) that the school running at ground plus two upper floors in a building comprised of ground plus three upper floors. Third floor is exclusively used as a storage area, with all rooms securely locked to prevent unauthorised access and there is no electricity supply on the third floor.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No. F.6/DFS/MS/SZ/2022/School/4461 dated 27.04.2022, renewal under rule, 37 of the Delhi Fire Service Rules, 2010 is recommended.


 Signature of Inspecting Officer
 Name: - R.K. Yadav
 Designation: - ADO (JKP)

DO (South West)


 1/7/25

CGO/
 2/7/2025

Director

PTO