



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001



No. F.6/DFS/MS/School/WZ/2025/ 744

Dated: 09/06/2025

FIRE SAFETY CERTIFICATE

Certified that the Govt. Co-ed, Sr. Sec. School, D-Block, Sultanpuri, Delhi-86. (School ID-1412088), comprised of 02 blocks, Ground + 03 upper floors, has already been issued FSC by this department vide letter No. F.6/DFS/MS/2022/School/WZ/435 dated 21.04.2022 for Gr. + 01 upper floor & F.6/DFS/MS/School/WZ/2022/516 dated 12.05.2022 for Gr. + 03 upper floors. The premises was re-inspected by the officer concerned of this department on 22.05.2025 in the presence of Mr. K. Muralidhar (Principal) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class **Group B Educational** with effect from 09/06/2025 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 09/06/2025 at New Delhi by


(Virendra Singh)
Chief Fire Officer

Copy to:

1. The Principal, Govt. Co-ed, Sr. Sec. School, D-Block, Sultanpuri, Delhi-86. (School ID-1412088).
2. The Director of Education, GNCT of Delhi Old Secretariat, Delhi-110054

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

INSPECTION REPORT

1. Name & address of the building : Govt. Co-ed, Sr. Sec. School, D-Block, Sultanpuri, Delhi-86
2. Type of Occupancy : Educational (School ID- 1412088)
3. Type of Case : Renewal (02 blocks, Gr. + 03 upper floors & Gr. + 01 floor)
4. Details of Previous NOC : F.6/DFS/MS/2022/School/WZ/435 dated 21.04.2022 for Gr.+01 & F.6/DFS/MS/School/WZ/2022/516 dated 12.05.2022 for Gr. + 03
5. Fire Safety directives letter No : DOE & NBC Part-IV
6. Date of inspection : 22.05.2025
7. Name of Inspecting Officer : A.K.Sharma ADO(Rohini)
8. Name and designation of officers
From the building side : Mr. K. Muralidhar (Principal)
9. Year of Construction : 1998, 2011 & 2021
10. Applicant's letter No. : Online e-mail dated 26.03.2022.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	DOE/NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	6.0m	12m	MR
	• Gate width	4.5m	6m	MR
	• Width of internal road	-NA-	-NA-	-NA-
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	New Blk-03 & 01 ramp Old Blk-01nos.	New Blk-03 & 01 ramp Old Blk-01nos.	MR MR
	• Basements	-NA-	-NA-	-NA-
	b. Width of staircases			
	• Upper Floor	New Blk -1.5m Old Blk-1.5m	New Blk -1.5m Old Blk-1.5m	MR
	• Basements	-NA-	-NA-	-NA-
	c. Protection of exits			
	Fire check door	-NA-	-NA-	-NA-
	• Pressurization	-NA-	-NA-	-NA-
	d. No. of continuous staircases to terrace	New blk-03nos.	Provided	MR
	e. Width of Corridor	New blk-1.5m	1.7m	MR
	f. Door Size	-NA-	-NA-	-NA-
3.	Compartmentation			
	• Fire check door	-NA-	-NA-	-NA-
	• Sealing of electrical shafts	-NA-	-NA-	-NA-
	• Fire Rating of shaft door	-NA-	-NA-	-NA-
	• Water Curtain	-NA-	-NA-	-NA-
	• Fire Dampers	-NA-	-NA-	-NA-
4.	Smoke Management System			
	• Basements	-NA-	-NA-	-NA-
	• Upper floors	12 a/c per hour	Natural ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	New Blk -42nos. Old Blk-08nos.	Provided	MR
	• Types	ABC/CO2	ABC/CO2	MR
	• IS marking	ISI marked	Yes	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	New Blk-04nos.	Provided	MR
	• Length of hose reel hose	30mm	Provided	MR

(Signature)

	• Nozzle diameter	5m	Provided		
7.	Automatic fire detection and alarming system				
	• Type of detectors	-NA-	-NA-		-NA-
	• Location of Main Panel	-NA-	-NA-		-NA-
	• Location of Repeater Panel	-NA-	-NA-		-NA-
	• Alternate source of power	-NA-	-NA-		-NA-
	• Hooters' Location	-NA-	-NA-		-NA-
8.	MOEFA	-NA-	-NA-		-NA-
9.	Public Address System	-NA-	-NA-		-NA-
10.	Automatic Sprinkler System				
	• Basement	-NA-	-NA-		-NA-
	• Ground & Upper Floors	-NA-	-NA-		-NA-
	• Sprinkler above false ceiling	-NA-	-NA-		-NA-
11.	Internal Hydrants				
	• Size of riser/down-comer	-NA-	-NA-		-NA-
	• Number of hydrants per floor	-NA-	-NA-		-NA-
	• Hose Box	-NA-	-NA-		-NA-
12.	Yard Hydrants				
	• Total number of hydrants	-NA-	-NA-		-NA-
	• Hose Box	-NA-	-NA-		-NA-
13.	Pumping Arrangements				
	• Ground Level				
	➤ Discharge of main Pump	-NA-	-NA-		-NA-
	➤ Head of Main pump	-NA-	-NA-		-NA-
	➤ Number of main pumps	-NA-	-NA-		-NA-
	➤ Jockey Pump out put	-NA-	-NA-		-NA-
	➤ Jockey pump head	-NA-	-NA-		-NA-
	➤ Standby Pump out put	-NA-	-NA-		-NA-
	➤ Standby Pump Head	-NA-	-NA-		-NA-
	➤ Auto Starting/Manual Stopping	-NA-	-NA-		-NA-
	➤ Pump House Access	-NA-	-NA-		-NA-
	• Terrace level				
	➤ Discharge of pump	New Blk-450lpm	2 x 450lpm		MR
	➤ Head of the pump	40m	40m		MR
	➤ Power Supply	Required	Provided		MR
	➤ Auto Starting of pump	Required	Provided		MR
14.	Captive Water Storage for fire fighting				
	• Underground tank capacity	-NA-	-NA-		-NA-
	➤ Draw-off connection	-NA-	-NA-		-NA-
	➤ Fire service inlet	-NA-	-NA-		-NA-
	➤ Access to tank	-NA-	-NA-		-NA-
	• Overhead Tank capacity	New Blk 10,000ltr	New Blk 20,000ltr		MR
15.	Exit Signage.	Required	Provided		MR
16.	Provision of Lifts.				
	• Pressurization of Lift Shaft	-NA-	-NA-		-NA-
	• Pressurization of Lift lobby	-NA-	-NA-		-NA-
	• Communication In lift Car	-NA-	-NA-		-NA-
	• Fireman's Grounding Switch	-NA-	-NA-		-NA-
	• Lift Signage	-NA-	-NA-		-NA-

Chf

	Standby power supply	-NA-	-NA-	-NA-
	Refuge Area.			
	➤ Total Area	-NA-	-NA-	-NA-
	➤ Location	-NA-	-NA-	-NA-
19.	Fire Control Room			
	• Detector System Panel	-NA-	-NA-	-NA-
	• Flow Switch Panel	-NA-	-NA-	-NA-
	• PA System Panel	-NA-	-NA-	-NA-
	• Battery backup	-NA-	-NA-	-NA-
	• Building Floor Plans	-NA-	-NA-	-NA-
20.	Special Fire Protection System for Protection of special Risks, if any:	-NA-	-NA-	-NA-


Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.


In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F.6/DFS/MS/2022/School/WZ/435 dated 21.04.2022 for Gr. + 01 upper floor & F.6/DFS/MS/School/WZ/2022/516 dated 12.05.2022 for Gr. + 03 upper floors is recommended for renewal under rule 37 of the Delhi Fire Service rules 2010.




Signature of the Inspecting Officer
Name Ajay Kumar Sharma
Designation ADO (Rohini)

DO (NW)


23/05/2022
dy cfo (w3)


26/5


cfo


26/5/2022

Director


dy cfo (w2)

put up F.T.


30/5/2022

ADO (Rohini)

Fi letter is put up for kind perusal and Signature please.


CFO (w2)

MS cell


2/6/22

DCFO/...15 NW
Dated...26/5/2022