

C-27
d/28

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE

No. F6/DFS/MS/School/2025/SZ/ 562

Dated: 30/04/2025

FIRE SAFETY CERTIFICATE

Certified that the **Fr. Peter Mermier Pre-School** located at C-1 Block, Janak Puri, New Delhi- 110058, comprised of basement and ground floor but school running at ground floor only, was issued FSC by this department vide letter No. F.6/DFS/MS/School/2022/SZ/451 dated 25.04.2022. The school building was re-inspected by the officer concerned of this department on dated 22.04.2025 in the presence of Principal, and found that the school management have deemed complied with the fire prevention and fire safety requirements in accordance with the Circular No. F.16/Estate/CC/Fire-Safety/2011/3298 to 3398 dated 01.03.2011, issued by the Director of Education and that the building/premises (**ground floor only**) is fit for occupancy class "**Educational Building**" w.e.f. 30/04/2025 for a period of three years, subject to compliance of the conditions printed as under.

Issued on 30/04/2025 at New Delhi by.


(Atul Garg)
Director
Delhi Fire Service
PC 294

Copy to: -

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.
2. The Principal, Fr. Peter Mermier Pre-School located at C-1 Block, Janak Puri, New Delhi- 58.

Conditions for the validity of fire safety certificate: -

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : Fr. Peter Mermier Pre School, C-1 Block, Janakpuri, New Delhi-110058
2. Building Comprised of : Basement and ground floor only but school running at ground floor only.
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC : F.6/DFS/MS/School/2022/SZ/451 dated 25.04.2022
6. Fire Safety directives letter No : N/A
7. Date of inspection : 22.04.2025
8. Name of Inspecting Officer : A.D.O. R.K. Yadav
9. Name and designation of officers
From the building side : Principal
10. Year of Construction : Before 2018
11. Applicant's letter No. : Nil dated 18.04.2019

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. of edu. Circular dt. 01.03.2011	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none">Road widthGate widthWidth of internal road	06 mtrs N/A N/A	Provided Directly accessible from road N/A	M/R N/A N/A
2.	Number, Width, Type & Arrangement of Exits			
	School running at GF only			
	a. Number of staircases			
	<ul style="list-style-type: none">Upper Floors	N/A	N/A	GF only
	<ul style="list-style-type: none">Basements	N/A	N/A	N/A
	b. Width of staircases			
	<ul style="list-style-type: none">Upper Floor	N/A	N/A	GF only
	<ul style="list-style-type: none">Basements	N/A	N/A	N/A
	c. Protection of exits			
	<ul style="list-style-type: none">Fire check door	N/A	N/A	N/A
	<ul style="list-style-type: none">Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace			
		N/A	N/A	N/A
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	100 cms	112 cms	M/R
3.	Compartmentation			
	<ul style="list-style-type: none">Fire check door	N/A	N/A	N/A
	<ul style="list-style-type: none">Sealing of electrical shafts	N/A	N/A	N/A
	<ul style="list-style-type: none">Fire Rating of shaft door	N/A	N/A	N/A
	<ul style="list-style-type: none">Water Curtain	N/A	N/A	N/A
	<ul style="list-style-type: none">Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	School at GF only			
	<ul style="list-style-type: none">Basements	Required	Provided	M/R
	<ul style="list-style-type: none">Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	<ul style="list-style-type: none">Total numbersTypesIS marking	04 no's ABC/CO ₂ type ISI marked	Provided	M/R
			Provided	M/R
			Provided	M/R
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none">Total numbers on each floorLength of hose reel hoseNozzle diameter	N/A N/A N/A	Provided Provided Provided	N/A N/A N/A

7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Ground Floor Sprinkler above false ceiling 	Required	Provided	M/R
		N/A	N/A	N/A
11.	Internal Hydrants	N/A	N/A	N/A
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	N/A	N/A	N/A
		N/A	N/A	N/A
12.	Yard Hydrants	N/A	N/A	N/A
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A	N/A	N/A
13.	Pumping Arrangements	N/A	N/A	N/A
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	N/A	N/A	N/A
		450 LPM	Provided	M/R
		40 mtrs	Provided	M/R
		Required	Provided	M/R
		Required	Provided	M/R
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		5000 ltrs	Provided	M/R
15.	Exit Signage.	N/A	N/A	N/A
16.	Provision of Lifts.	No Lift		
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A


N/S

17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules the Fire Safety Certificate was issued vide letter No. F.6/DFS/MS/School/2022/SZ/451 dated 25.04.2022, renewal in accordance with the Circular No. F.16/Estate/CC/Fire-Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education, is recommended.


Note: - As per the undertaking submitted by the Head Mistress (placed at C-22) the basement is not used for schooling purpose and the seating capacity per class is less than 45.


 Signature of Inspecting Officer
 Name: - R.K. Yadav
 Designation: - ADO (JKP)

DO (South West)



25/4/25


 25/4/2025

Director

