

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No.F.6/DFS/MS/School/2026/Outer-North/ 112

Dated: 28/07/2026

FIRE SAFETY CERTIFICATE

Certified that the building of **French Public School**, located at **Safiabad Road, Gali no. 10-11 Sanjay Colony, Narela, Delhi-110040** comprised of Ground floor only, have complied with the fire prevention and fire safety requirements in accordance with the rule 33 of the Delhi Fire Service, 2010 and verified by the officer concerned of this department on 15/07/2026 in the presence of Sh. Akshay Kumar (Owner) and that the said premises/building is fit for occupancy class "**Educational (School), Group B**" with effect from 28/07/2026 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 28/07/2026 at New Delhi by.


(Dr. S. K. Tomar)
Chief Fire Officer
Delhi Fire Service
OIC

Copy to: -

1. Sh. Akshay Kumar (Owner), M/s French Public School, located at Safiabad Road, Gali no. 10-11 Sanjay Colony, Narela, Delhi-110040.
2. The Director of Education, MCD, Dr. SPM Civic Centre, JLN Marg, New Delhi-110002.

Condition for the validity of fire safety certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. The trained firefighting staff should be available at the site round the clock.
6. Any deviation with regard to the construction etc. shall be verified by the concerned building sanctioning authority.
7. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. This fire safety certificate may not in any way be treated as regularization of unauthorized construction, if any. Basement shall be used as per BBL concerned.
9. "The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

INSPECTION REPORT

1.	Name & address of the building	French Public School, at Safiabab Road Gali no. 10-11 Sanjay Colony, Narela, Delhi-110040.		
2.	Type of occupancy	Educational, Group B (School)		
3.	Building Comprised of	Ground floor only		
4.	Type of case	New Case		
5.	Details of previous FSC No.	Nil		
6.	Fire safety directives No.-	Directorate of Education Cir. 01/03/2011		
7.	Date of inspection: -	15/07/2026		
8.	Name of the inspecting officer: -	Nitin Lohchab, ADO (BW)		
9.	Name & designation of officer from the building side: -	Sh. Akshay Kumar (Owner)		
10.	Year of construction: -	2000		
11.	Applicant's Online ID./letter No: -	Form 'I' received through mail on dated 14/07/2026		
S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	Directorate of Education Circ. 01/03/2011	Provided at site	Remarks MR/NMR
1.	Access to Building			
	• Road width	6 Mtr	Provided	MR
	• Gate width	4.5 m	Directly Accessible	MR
	• Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper floors	N/A	N/A	N/A
	• Basements	N/A	N/A	N/A
	b. Width of staircase			
	• Upper floors	N/A	N/A	N/A
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	N/A	N/A	N/A
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	01 m	Provided	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain (Basement)	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	• Basements	N/A	N/A	N/A

N/2

	• Upper floors	Required	Natural ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	04 nos.	Provided	MR
	• Types	ABC/CO2	ABC & CO2	MR
	• ISI marking	ISI Marked	Provided	MR
6.	First-Aid Hose Reel			
	• Total number of each floor	N/A	N/A	N/A
	• Length of hose reel hose	N/A	N/A	N/A
	• Nozzle diameter	N/A	N/A	N/A
7.	Automatic Fire Detection & Alarming System.			
	• Type of detectors (Smoke)	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basement	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	Ground level			
	• Discharge of main pump	N/A	N/A	N/A
	• Head of main pump	N/A	N/A	N/A
	• Number of main pumps	N/A	N/A	N/A
	• Jockey pump out put	N/A	N/A	N/A
	• Jockey pump head	N/A	N/A	N/A
	• Stand by pump output	N/A	N/A	N/A
	• Stand by pump head	N/A	N/A	N/A
	• Auto starting/Manual stopping	N/A	N/A	N/A
	• Pump House Access	N/A	N/A	N/A
	Terrace level			
	• Discharge of pump	N/A	N/A	N/A
	• Head of pump	N/A	N/A	N/A



2/3

	• Power supply	N/A	N/A	N/A
	• Auto starting of pump	N/A	N/A	N/A
14.	Captive Water Storage for Fire Fighting			
	• Underground tank capacity	N/A	N/A	N/A
	• Draw-off connection	N/A	N/A	N/A
	• Fire service inlet	N/A	N/A	N/A
	• Access to tank	N/A	N/A	N/A
	• Overhead tank capacity	N/A	N/A	N/A
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of lift shaft	N/A	N/A	N/A
	• Pressurization of lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Fireman's switch	N/A	N/A	N/A
	• Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	N/A	N/A	N/A
18.	Refuge Area			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19.	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:	N/A	N/A	N/A

The fire protection systems provided in the building/ premises were checked, tested at random and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum fire safety standards on fire prevention and fire safety measures as required under the rules, it is recommended to issue Fire safety certificate (FSC) to said school.

Accordingly, **DFA is put up for approval & signature please.**

Nitin Lohchab
15/7/26
Nitin Lohchab
ADO (BW)

~~DO/Outer North~~

DFA Pl.

~~CFO(O/North)~~

[Signature]
15/7/26

~~Principal Director~~

[Signature]
15/7/26

CFO Ad issue.

~~CFO~~

[Signature]
24/7/26

ADO(BW)

[Signature]
24/7/26