

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/WZ/2024/ 05

Dated: 02/01/2024

To,

Mr. Satish Kumar Garg (Owner),
G3S Cinema, Plot No.6,
Garg Trade Centre, Community Center,
Sector 11 Rohini,
Delhi 110085.

Sub: Issue of FSC in r/o G3S Cinema, Plot No.6, Garg Trade Centre, Sector 11 Rohini, Delhi 110085.

Sir,

Kindly reference to online e-mail dated 04.12.2024, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on **18.12.2024**, in presence of **Mr. Satish Kumar Garg (Owner)**, to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. Diesel pump in pump house not functional.
2. FCD found removed at top floor of staircase.
3. Beam detectors in cinema hall not functional.
4. Foyer area smoke ventilation found removed.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:

http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules
[/http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms)

Yours faithfully


(Atul Garg)
DIRECTOR
Ph: 011-23414000