

C/141

FORM 'H': FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[See sub-rule (1) of rule 35]  
**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No.F.6/DFS/MS/School/2025/ 343

Dated: 24/06/2025

**FIRE SAFETY CERTIFICATE**

Certified that the M/s Gagan Cinema located at Nand Nagri, Delhi-110093, building comprised of Basement (Sealed), Ground plus two upper Floors owned / occupied by Gagan Cinema was issued FSC vide letter No. F6/DFS/MS/Cinema/2022/NDZ/200 dated 09/05/2022. The premises was re-inspected by the officer concerned of this department on 12/06/2025 in presence of Sh. Rakesh Kumar (Manager) and observed that all the Fire Prevention and Fire Safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with rule 33 of the Delhi Fire Service Rules, 2010 and that the building / premises is fit for occupancy class "Assembly" (Cinema) with effect from 24/06/2025 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010.

Issued on 24/06/2025 at New Delhi by.

(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE.

Copy to :-

1. Manager, Gagan Cinema, Nand Nagri, Delhi-110093.
2. The District Magistrate, Nand Nagri District, East Delhi-110093

**Conditions for the validity of Fire Safety Certificate:**

1. Basement is Sealed (Brick wall) by the MCD (Under Taking given by owner.
2. Fire Safety Certificate is valid Ground & Two Upper Floors only.
3. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
4. Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
5. The trained fire fighting staff should be available round the clock.
6. Any deviation with regard to the construction etc. shall be verified by the concerned building sanctioning agency.
7. This certificate cannot be treated in any case for regularizations of unauthorized construction.
8. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
9. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in)



# INSPECTION REPORT

1.	Name & address of the building	Gagan Cinema, Nand Nagri, Delhi-110093		
2.	Type of Occupancy	Assembly Building Cinema Single Screen		
3.	Building Comprised of	Ground plus 2 upper floors		
4.	Type of Case	Renewal		
5.	Details of previous NOC	F6/DFS/MS/Cinema/2022/NDZ/200 dt. 9/5/22		
6.	Fire Safety directives Letter No	The Delhi Cinematograph Rules 1983		
7.	Date of Inspection	12.06.2025		
8.	Name of the Inspecting Officer	A.K. Jaiswal, D.O. (East)		
9.	Name and Designation of Officer from the building side	Sh. Rakesh Kumar (Manager)		
10.	Year of Construction	2006		
11.	Applicant's letter No.	Email dated 06/06/2025		
S. No	Minimum standards on fire prevention and fire safety U/R 33	Requirement Cinematograph Act, 1983	Provided at site	Remarks MR/NMR
1.	Access of building	12m	30m	MR
	• Road width	Required	Provided	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases	2	2	MR
	• Upper floors	Sealed	Sealed	Sealed
	• Basements			
	b. Width of staircases	1.50m	2.80m each	MR
	• Upper floors	Sealed	Sealed	Sealed
	• Basements			
	c. Protection of exits	NA	NA	NA
	• Fire check door	NA	NA	NA
	• Pressurization	2	2	MR
	d. No of continuous staircase to terrace	1.5m	1.70m	MR
	e. Width Of Corridor	1.50m	2.80m x 2 &	MR
	f. Door Size	1.50m	1.50m x 3	MR
	Balcony	1.50m	1.50m x 3	MR
	Dress Circle	1.50m	1.50m x 3	MR
	Front Circle			
3.	Compartmentation	NA	NA	NA
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System	12ACPH	Sealed	NA
	• Basements	30 ACPH	Exhaust Fan	MR
	• Upper floors			
5.	Fire Extinguishers	48	48	MR
	• Total numbers	ABC / CO <sub>2</sub>	Provided	MR
	• Types	ISI Marked	Provided	MR
	• ISI marking			
6.	First – Aid Hose Reels	2	2	MR
	• Total numbers on each floor	30 mtr	30 mtr	MR
	• Length of hose reel hose	5 mm	5 mm	MR
	• Nozzle diameter			




7.	Automatic fire detection and alarming system			
	• Type of detector	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	• Size of riser/down- comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	Required	1	MR
	• Hose Box	Required	1	MR
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 LPM	450 LPM	MR
	➤ Head of the pump	40 mtr	40 mtr	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	25,000 ltr	50,000 ltr	MR
	➤ Draw of connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	20,000 ltr	33,000 ltr	MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA

N/94

19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/DFS/MS/Cinema/2022/NDZ/200 dt. 9/5/22 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

  
 Signature of the Inspecting Officer  
 Name : Ashok Kumar Jaiswal  
 Designation: D.O. (East)

Dy. C.F.O. (NDZ)

*Kirp*  
17/06/25

C.F.O.

*Vueg*  
19/6/2025

Director

*hy*  
20/06/25

~~DOE~~

As Approved, F.I. Letter is put up for sign off.

*hy*  
23/06/25

Director

*hy*  
27/6/25

*n*