

No. F.6/DFS/MS/2025/GH/10

Dated: 07/01/2025

FIRE SAFETY CERTIFICATE

Certified that the building of M/s Gagan Guest House Located at Cottage No. 15, West Patel Nagar, New Delhi-110008, in a building comprised of Basement, stilt, ground plus three upper floors using Basement (storage), stilt as parking, ground floor (Reception & 07 guest rooms) first floor 07 guest rooms & second floor having 06 guest rooms & third floor having 05 guest rooms) (Total=25 guest rooms) & Small temporary tin shed on terrace (now sealed/closed) was issued FSC vide letter No. F6/DFS/MS/GH/SZ/2021/410, dated 23/09/21. The premises was re inspected by the officer concerned of this department on 30/12/2024 in the presence of Sh. Hasan Parveez (Manager) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "Residential" (guest house) at **ground floor (Reception & 07 guest rooms) first floor 07 guest rooms & second floor having 06 guest rooms & third floor having 05 guest rooms) (Total=25 guest rooms)** with effect from 07/01/2025 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ...07/01/2025 at New Delhi by.

(Ardi Garg)
Director
Delhi Fire Service

Copy to:

1. The Joint. Commissioner of Police (Lic), 1st Floor, Licensing Unit, Police Station, Defence Colony, New Delhi, online ID no. 2024100815407 dated 12.12.2024.
2. The Executive Engineer (Building), MCD, Civic Centre, Minto Road, New Delhi for information w.r.t. the use of the basement.

Condition for the validity of fire safety certificate

1. **Terrace floor shall not be used for any purpose as undertaking given by owner**
2. **Basement sealed by close by MCD, photograph attached.**
3. The staircase at terrace level shall be kept open & free from lock and key & all the exit shall be clear from any obstruction otherwise the FSC shall be null & void
4. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
5. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
6. The trained staff should be available round the clock.
7. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
8. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
9. The basement shall be used as per building bye laws.
10. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
11. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building: M/s Gagan Guest House Located at Cottage No. 15, West Patel Nagar, New Delhi-110008.
2. Type of Occupancy : Lodging or rooming "A-1"
3. Type of Case : Renewal (Running at Gf, 1st, 2nd, & 3rd floor in a building comprised of Basement, Stilt + Ground + 3 Upper Floor)
4. Details of previous NOC : F6/DFS/MS/GH/SZ/2021/410, dated 23/09/21
5. Fire Safety directives Letter No. : Nil
6. Date of inspection : 30/12/2024
7. Name of the Inspecting Officer : ADO Suman
8. Name and designation of Officer
from the building side : Sh. Hasan Parveez (Manager)
9. Year of Construction : 2010
10. Applicant's letter No. : 2024100815407, dated 10/12/2024

| S No | Minimum standards on fire prevention and fire safety U/R 33 | As per N/7, N/8 & N/9 | Provided at site | Remarks MR/NMR |
|------|---|-----------------------|-----------------------------|----------------|
| 1. | Access of building | 6 mtr | Provided | MR |
| | • Road width | 4.5m | Direct accessible from road | MR |
| | • Gate width | NA | NA | NA |
| | • Width of internal road | NA | NA | NA |
| 2. | Number, width, Type & Arrangements of exits | | | |
| | a. Number of staircases | 01 | 01 | MR |
| | • Upper floors | NA | NA | Scaled by MCD |
| | • Basements | | | |
| | b. Width of staircases | 1.25m | Provided | MR |
| | • Upper floors | NA | NA | Scaled by MCD |
| | • Basements | | | |
| | c. Protection of exits | Required | Provided at II & III floors | MR |
| | • Fire check door | NA | NA | NA |
| | • Pressurization | 01 | 01 | MR |
| | d. No of continuous staircase to terrace | NA | NA | NA |
| | e. Width Of Corridor | 1.25 m | Provided | MR |
| | f. Door Size | | | |
| 3. | Compartmentation | | | |
| | • Fire check door | Required | Provided at II & III floors | MR |
| | • Sealing of electrical shafts | Required | Provided | MR |
| | • Fire Rating of shaft door | NA | NA | NA |
| | • Water Curtain | NA | NA | NA |
| | • Fire Dampers | NA | NA | NA |
| 4. | Smoke managements System | | | |
| | • Basements | NA | NA | Scaled by MCD |
| | • Upper floors | 12 a/c per hour | Provided | MR |

| | | | | | |
|-----|--|--|-------------------------|-----------------------|----|
| 5. | Fire Extinguishers | 16 Nos. ABC & CO ₂ Required | | Provided | MR |
| | • Total numbers | | | CO ₂ & ABC | MR |
| | • Types | | | Provided | MR |
| | • IS marking | | | | |
| 6. | First – Aid Hose Reels | | | | |
| | • Total numbers on each floor | 01 | | Provided | MR |
| | • Length of hose reel hose | 30 mtr | | Provided | MR |
| | • Nozzle diameter | 5 MM | | Provided | MR |
| 7. | Automatic fire detection and alarming system | | | | |
| | • Type of detectors | CO detectors | | Provided | MR |
| | • Location of Main Panel | Required | | Provided | MR |
| | • Location of Repeater Panel | NA | NA | | NA |
| | • Alternate source of power | Required | Provided DG set 125 kva | | MR |
| | • Hooters' Location | NA | NA | | NA |
| 8. | MOEFA | Required | Provided | | MR |
| 9. | Public Address System | Required | Provided | | MR |
| 10. | Automatic Sprinkler System | | | | |
| | • Basements | NA | NA | Sealed by MCD | |
| | • Upper Floor | NA | NA | | NA |
| | • Sprinkler above false ceiling | NA | NA | | NA |
| 11. | Internal Hydrants: | | | | |
| | • Size of riser/down- comer | NA | NA | | NA |
| | • Number of hydrants per floor | NA | NA | | NA |
| | • Hose Box | NA | NA | | NA |
| 12. | Yard Hydrants | | | | |
| | • Total number of hydrants | NA | NA | | NA |
| | • Hose Box | NA | NA | | NA |
| 13. | Pumping Arrangements: | | | | |
| | • Ground Level | | | | |
| | • Discharge of main pump | NA | NA | | NA |
| | ➤ Head of main pump | NA | NA | | NA |
| | ➤ Number of main pumps | NA | NA | | NA |
| | ➤ Jockey pump out put | NA | NA | | NA |
| | ➤ Jockey pump head | NA | NA | | NA |
| | ➤ Standby Pump out put | NA | NA | | NA |
| | ➤ Standby Pump Head | NA | NA | | NA |
| | ➤ Auto Staring/Manual stopping | NA | NA | | NA |
| | ➤ Pump House Access | NA | NA | | NA |
| | • Terrace level | | | | |
| | ➤ Discharge of pump | 900 lpm | Provided | | MR |
| | ➤ Head of the pump | 30 mtrs | Provided | | MR |
| | ➤ Power supply | Required | Provided | | MR |
| | ➤ Auto starting of pump | Required | Provided | | MR |
| 14. | Captive water Storage for fire fighting: | | | | |
| | • Under ground tank capacity | NA | NA | | NA |
| | ➤ Draw off connection | NA | NA | | NA |
| | ➤ Fire service inlet | NA | Provided | | NA |
| | ➤ Access to tank | NA | NA | | NA |
| | • Overhead Tank capacity | 10000 ltr | 10000 ltr | | MR |

NB-17

| | | | | |
|-----|--|----------|----------|----|
| 15 | Exit Signage | Required | Provided | MR |
| 16. | Provision of Lifts | | | |
| | ➤ Pressurization of Lift Shaft | NA | NA | NA |
| | ➤ Pressurization of lift lobby | NA | NA | NA |
| | ➤ Communication in lift Car | Required | Provided | MR |
| | ➤ Fireman's Grounding Switch | Required | Provided | MR |
| | ➤ Lift Signage | Required | Provided | MR |
| 17. | Standby power supply | Required | Provided | MR |
| 18. | Refuge Area | | | |
| | ➤ Total area | NA | NA | NA |
| | ➤ Location | NA | NA | NA |
| 19. | Fire control room | | | |
| | ➤ Detector system panel | NA | NA | NA |
| | ➤ Flow Switch Panel | NA | NA | NA |
| | ➤ PA System Panel | NA | NA | NA |
| | ➤ Battery backup | Required | Provided | MR |
| | ➤ Building Floor Plans | NA | NA | NA |
| 20. | Special Fire Protection Systems for Protection of special Risks, if any; | NA | NA | NA |

The fire protection systems provided in the building were test checked and found functional at the time of inspection. *shortcomings issued on 21/5/24 found complied with*

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the FSC issued vide letter No. F6/DFS/MS/GII/SZ/2021/410, dated 23/09/21 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended. If approved the FSC may be issued.

Note → Photograph & affidavit are placed C-56 to C-61

01/01/25
Signature of the Inspecting Officer
Name: *SUMAN KUMAR*
Designation: *ADD*

Do (SW)

21/1/25

3/01/2025

Director
21/1/25

Any/sum

F.T. letter is put up for sig. by

Director
21/1/25

06/01/25
SUMAN K (ADD)

Updated