

C47



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001



No F 6 / DFS / MS / 2025 / School / WZ / 649

Dated 13/05/2025

FIRE SAFETY CERTIFICATE

Certified that the **Ganga International School** located at **Sawda, Ghevra- Nizampur Road, Delhi-110081** comprised of **Ground plus First floor** was issued FSC by this department vide letter No F6/DFS/MS/2022/School/WZ/244 dated 09.03.2022. The premises was re-inspected by the officer concerned of this department on 02.05.2025 in the presence of Smt. Prerana Chauhan (Principal), and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education vide letter no 262-362 dated 17.01.2005 and the building/ premise is fit for occupancy Group B Educational with effect from13/05/2025 for a period of three years, subject to compliance of the conditions mentioned below:

Issued on13/05/2025 at New Delhi by

(Atul Garg)
 Director

Ph. 011-23414000

Copy to:-

1. The Director, Education, Government of NCT of Delhi. Old Sect. Delhi-110054
2. The Principal, Ganga International School located at Sawda, Ghevra- Nizampur Road, Delhi-110081.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigov.nic.in
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

INSPECTION REPORT

1. Name & address of the building : Ganga International School, located at Sawda, Ghevra- Nizampur Road, Delhi- 110081.
2. Type of Occupancy : Educational
3. Building Comprised of : Ground + First Floor.
4. Type of Case : Renewal
5. Details of Previous NOC : F6/DFS/MS/2022/School/WZ/244 dated 09/03/2022
6. Fire Safety directives letter No : DOE circular No. 262-362 dated 17/01/2005
7. Date of inspection : 02/05/2025
8. Name of Inspecting Officer : R.K.Sinha, ADO (BW)
9. Name and designation of officers
From the building side : Smt. Prerana Chauhan (Principal)
10. Year of Construction : 2006-2010
11. Applicant's letter No. : Outdoor Diary No. 14914 dated 24/03/2025

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	DOE Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	6 m	6 m	MR
	• Gate width	5 m	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	03	03	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floor	1.50 m	Provided	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	1.5 m	Provided	MR
	f. Door Size	1 m	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	• Basements	NA	NA	NA
	• Upper floors	Required	Naturally Ventilated	MR
5.	Fire Extinguishers			
	• Total numbers	14	Provided	MR
	• Types	ABC Type	Provided	MR
	• IS marking	Required	Provided	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	02	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA

N-19

8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			NA
	• Basement	NA	NA	NA
	• Ground Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			NA
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			NA
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level			NA
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual Stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	Required	Provided	MR
	➤ Head of the pump	Required	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	2500 ltrs	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire Control Room			


2/20

	• Detector System Panel	NA		
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Note- Electric meter and electrical panel are at safer location.

Keeping in view of deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, it is recommended to renew the Fire Safety Certificate issued vide letter number F6/DFS/MS/2022/School/WZ/244 dated 09/03/2022 under Rule 35 of the Delhi Fire Service Rules, 2010.


 Signature of Inspecting Officer
 Name : Rajeev Kumar Sinha
 Designation : ADO/B.W.





 06/05/2025

 Dy CPO (WZ)


 27/05/2025

1183-NKP
 27/05/25

CPO/

 01/05/2025
 Director

 01/05/21


 ADO/BW

Sr. FT letter is sent for your file


 13/5/25


 Director