



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



C/41

No. F6/DFS/MS/Industry/WZ/2025/ 176

Dated: 09 / 04 / 2025

FIRE SAFETY CERTIFICATE

Certified that the M/s. Galaxy Automobiles Pvt. Ltd. Located at 69/1A, Najafgarh Road, Moti Nagar, New Delhi-110015, in a building comprised of Basement + Ground + First Floor, was issued FSC vide letter No. F6/DFS/MS/WZ/2020/479 dated 06/11/2020, The building/premises was re-inspected by the officer concerned of this department on 19/03/2025 in the presence of Sh. Pardeep Wadhwa and found that the said premises/building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises/building is fit for occupancy class "Industry" (Group - G) with effect from 09/04/2025 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 conditions mentioned below.

Issued on 09/04/2025 at New Delhi by.

(Atul Garg)
Director

Copy to: -

1. The Commissioner MCD, Civic Centre, Minto Road, New Delhi- 110002.
2. The Dy. Director (Bldg), DDA, INA, Vikas sadan, New Delhi.
3. The Executive Engineer – I(Bldg.)HQ, NDMC, 9th Floor Civic Center Minto Road, New Delhi-110002.
4. Sh. Pardeep Wadhwa, M/s. Galaxy Automobiles Pvt. Ltd. Located at 69/1A, Najafgarh Road, Moti Nagar, New Delhi-110015.

Conditions for the validity of FSC:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency/MCD.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per BBL laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1.	Name & address of the building	M/s. Galaxy Automobiles Pvt. Ltd. Located at 69/1A, Najafgarh Road, Moti Nagar, New Delhi-110015.
2.	Type of Occupancy	Industry (Basement + Ground + First Floor)
3.	Type of Case	Renewal
4.	Details of previous NOC	F6/DFS/MS/WZ/2020/479 dated 06/11/2020
5.	Fire Safety directives letter No	F6/DFS/MS/BP/96/1537 dated 19/11/1996
6.	Date of inspection	19/03/2025
7.	Name of the Inspecting Officers	Sarabjeet Singh ADO (MN)
8.	Name and designation of officers from the building side	Sh. Pardeep Wadhwa
9.	Year of Construction	1996
10.	Applicant's letter No.	Outdoor diary No 14417 dated 12/03/2025

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	As per Rule 35 (6) DFS Rule 2010	Provided at site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	09mts 05m NA	On Road 5.4 & 3.5 mts NA	MR MR NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper Floors Basements 	02 nos. in A-Block NA	02 nos. in A-Block NA	MR NA
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floors Basements 	1.2m 1.2m	Provided Provided	MR (Old Case) MR (Old Case)
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	NA NA	NA NA	NA NA
	d. No. of continuous staircases to terrace	01	Provided	MR
	e. Width of Corridor	1.2m	Provided	MR (Old Case)
	f. Door Size	1.2m	Provided	MR (Old Case)
3	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	Required at internal stair in basement NA NA NA NA	Wired Glass smoke check door Provided NA NA NA NA	MR NA NA NA NA
4	Smoke Management System.			
	<ul style="list-style-type: none"> Basements Upper floors 	Required NA	Provided (Exhaust Fan) NA	MR NA
5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	40 nos. CO ₂ , ABC type ISI marked	Provided Provided Provided	MR MR MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	03 30 mtrs 5 mm	Provided Provided Provided	MR MR MR

7	Automatic fire detection and alarming system.			
	• Type of detectors	Required	Provided	MR
	• Location of Main Panel	Required	Provided	MR
	• Location of Repeater Panel	Required	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public Address System.	NA	Provided	NA
10	Automatic Sprinkler System.			
	• Basement	Required	Provided	MR
	• Upper Floor	NA	Provided in GF	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	03	Provided	MR
	• Number of hydrants per floor	Required	Provided	MR
	• Hose Box	Required	Provided	MR
12	Yard Hydrants.			
	• Total number of hydrants	Required	Provided	MR
	• Hose Box	Required	Provided	MR
13	Pumping Arrangements.			
	• Ground Level	2 x 2850lpm	Provided	MR
	➤ Discharge of main Pump	50m	Provided	MR
	➤ Head of Main pump	02	Provided	MR
	➤ Number of main pumps	450lpm	Provided	MR
	➤ Jockey Pump out put	50m	Provided	MR
	➤ Jockey pump head	2850lpm	Provided	MR
	➤ Standby Pump out put	50m	Provided	MR
	➤ Standby Pump Head	Required	Provided	MR
	➤ Auto Starting/ Manual stopping	Required	Provided	MR
	➤ Pump House Access			
	• Terrace level	NA	NA	NA
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power Supply	NA	NA	NA
	➤ Auto Starting of pump	NA	NA	NA
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	2,00,000ltrs	Provided	MR
	➤ Draw-off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	15,000 lt	Provided	MR
		Required	Provided	MR
15	Exit Signage.			
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	NA	NA	NA

Refuge Area.		NA	NA	NA
➤ Total Area		NA	NA	NA
➤ Location				
Fire Control Room		NA	NA	NA
• Detector System Panel		NA	NA	NA
• Flow Switch Panel		NA	NA	NA
• PA System Panel		NA	NA	NA
• Battery backup		NA	NA	NA
• Building Floor Plans		NA	NA	NA
20 Special Fire Protection Systems for Protection of special Risks, if any:				

The fire protection systems provided in the building were checked and found functional at the time of inspection. Earlier all the shortcomings issued by this department have been complied by the management of building.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules, the NOC vide letter no F6/DFS/MS/WZ/2020/479 dated 06/11/2020, renewal under the rule 35 of the Delhi Fire Service rules 2010 is recommended.

C/ADO/MN
10/03/2025

~~24 CPO (10/2)~~

~~Signature of the Inspecting Officer
Sarabjeet Singh ADO (MN)~~

607 WZ
Date: 20/3/2025

CPO

~~20/3/2025~~

~~11/4/2025~~

~~Director~~

~~MN~~

Sir, F-7 is put up for your kind personal obj. pls.!

~~Director~~

~~20/4/2025~~