

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI

No. F6/DFS/MS/SZ/2026/ **308**

Dated: **22 / 07 /2026**

To,

The Commissioner MCD,
Civic Centre, Minto Road,
New Delhi- 110002.

Sub: Regarding issuance of FSC from fire safety point of view in r/o M/s Galaxy Toyota (A Unit of Galaxy Automobiles Pvt. Ltd.). located at Plot no. 84, Okhla Industrial Area Phase-I, New Delhi-110020.

Sir,

Please refer to your online application no. No. 52026051502934, on the subject cited above. In this connection, it is to inform you that the premises was inspected by officer concerned of this department on 05/07/2026 in the presence of Sh. Devender Bist (G.M) the following shortcomings were observed during inspection.

1. Yard hydrants are provided but not functional.
2. Main Fire Pump capacity of 2280 LPM is provided but not on auto mode.
3. Draw-off connection & Fire service inlet are found removed.
4. Water curtain found removed in car lift.

In view of above Shortcomings, the application for renewal of Fire Safety Certificate is cannot consider at this stage. The occupancy of the building/premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier.

Yours faithfully,


(A.K. Malik)
Chief Fire Officer

Copy To: -

1. The Owner/occupier r/o M/s Galaxy Toyota (A Unit of Galaxy Automobiles Pvt. Ltd.). located at Plot no. 84, Okhla Industrial Area Phase-I, New Delhi-110020. (Online application No. 52026051502934).