



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6 /DFS/MS/Industrial/SZ/2025/ 153

Dated: 07/04/2025

To,

The Owner/Occupier/Manager,
M/s Galaxy Toyota (A Unit of Galaxy Automobiles Pvt. Ltd.)
Plot no. 84, Okhla Industrial Area Phase-I, New Delhi-20.

Sub: - Regarding renewal of Fire Safety Certificate in r/o M/s Galaxy Toyota (A Unit of Galaxy Automobiles Pvt. Ltd.) located at Plot no. 84, Okhla Industrial Area Phase-I, New Delhi-20

Sir,

With reference to the your email dated 10.03.2025 on the subject cited above, it is informed that the said building was inspected by officer concerned of this department on 26.03.2025 in the presence of Mr. Devender Singh Bisht (Manager) and following shortcomings were observed:

1. Fire Check Door (FCD) found removed in basement.
2. Poor Ventilation system in basement.
3. Automatic Fire Detection and Alarming System (ADAS) found non function.
4. Manual Operated Electrical Fire Alarm (MOEFA) system found non functional.
5. All water based systems like Hose reels Internal & Yard Hydrants, Sprinklers, Fire Pumps are non functional.
6. Water curtains found not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)

Director

Delhi Fire Service

Copy to:-

1. The Executive Engineer (Building), South DMC, Jal Vihar, Lajpat Nagar, New Delhi-24.