

No. F6/DFS/MS/GH/NDZ/2025/BNUT/06

Dated: 29/01/2025

To,

The Joint Commissioner of Police (Lic.),
1st floor, Police Station Defence Colony,
New Delhi – 110024.

Subject: - Regarding grant of Fire Safety Certificate in r/o M/s Garg Celebration (A Unit of Garg Enterprises) located at Property No. C – 24 & 25 First, Second floor, Acharya Niketan, Mayur Vihar Phase – I, Delhi - 110091.

Sir,

This has a reference to MHA application No. 2025011500517 dated 15/01/2025, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 22/01/2025 in the presence of Mr. Jatin Garg (Owner) and observed that building comprised of Ground + Mezzanine + 1st & 2nd floor (Banquet Hall running on 1st & 2nd Floor only)

Following shortcomings were observed during time of inspection:

1. Fire Check doors found removed.
2. Door sizes of 1st floor are 1.50 meters & 1.30 meters and 2nd floor are 1.80 meter & 1.30 meter against requirement of 2 meters width at each floor.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

o/c DELHI FIRE SERVICE

Copy to:-

1. The Manager, M/s Garg Celebration (A Unit of Garg Enterprises) located at Property No. C – 24 & 25, First, Second floor, Acharya Niketan, Mayur Vihar Phase – I, Delhi - 110091.