

 GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001



No. F6/DFS/MS/EH/SZ/2026/ 320

Dated: 14 / 04 /2026

To,

The Commissioner MCD,
Civic Centre, Minto Road,
New Delhi- 110002.

Sub: Regarding renewal of FSC from fire safety point of view in r/o. M/s Gastronomica Kitchen and Bar A Unit Of Vagabonds Restaurant Pvt at M-55, Second Floor M-Block Market Greater Kailash Part-1. New Delhi-110048.

Sir,


Please refer to your online application no. Online-ID No -2026031002615 dated-10/03/2026, 20260330502375 dated-06/03/2026 on the subject cited above. In this connection, it is to inform you that the premises was inspected by officer concerned of this department on 06/04/2026 in the presence of Sh. Sanjay to see the functioning of fire safety equipments provided in the building.

During inspection, it has been observed that the said eating house is running at second floor in a building comprised of ground + 02 upper floors, was issued FSC vide letter no. F.6/DFS/MS/EH/2023/SZ/89 dated-06/03/2023. Fire safety arrangements such as Fire Extinguishers, MOEFA etc provided. However the following shortcomings were observed.

1. Fire check door found removed.
2. Smoke management system found removed.
3. Exit signage's are found removed.

In view of above shortcomings, the application for renewal of Fire safety Certificate is cannot considered at this stage & rejected. The occupancy of the Building/premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier.

Yours faithfully,


(A.K. Malik)
Chief Fire Officer

Copy To: -

1. The Owner/occupier M/s Gastronomica Kitchen and Bar A Unit Of Vagabonds Restaurant Pvt at M-55, Second Floor M-Block Market Greater Kailash Part-1. New Delhi-110048. Online application No. 2026031002615 dated-10/03/2026, 20260330502375 dated-06/03/2026