

C/6

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

Dated. 09/01/2025

No.F.6/DFS/MS/2025/ 19

To,

Sh. Gaurav Khanna,
Authorized Signatory,
G-34, GF, Jangpura Extension,
New Delhi-110014.

Sub:- Regarding issuance of FSC to Gati Shakti and ODOP Experiential Centre- Anubhuti Kendra for DPIIT (Departmental for Promotional of Industry and Internal Trade) for mezzanine floor at Hall No. 14 at ITPO, New Delhi.

Sir,

This has a reference to your Mail id <mailto:gaurav.achiles@nic.in> dated 13.12.2024, on the subject cited above, it is to inform you that the site was inspected from fire safety point of view by the officers concerned of this department on 03/01/2025 in the presence of Mr. Krishna & Sh. Amit Chikara, fire officer, ITPO and following shortcomings were observed:-

1. Alternate exit near control room shall be provided and same shall not be less than 1.5 meters in width.
2. Smoke venting arrangements not provided.
3. All the wooden paneling/ temporary structure/cloth are required to be treated with fire retardant paint.

In view of above, the fire safety certificate FSC cannot be issued to the mezzanine floor. Therefore, you are requested to rectify the above shortcomings for further consideration in the matter.

Yours faithfully,


(Atul Gang)
DIRECTOR
Delhi Fire Service

Copy to:-

1. The GM (Security), ITPO, Pragati Maidan, New Delhi.