

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/School/2025/ 188

Dated: 03/04/2025

To

Ms. Meenakshi Aggarwal (Administration),
Elisabeth Gauba School, Sector-II, DIZ,
Area, Kali Bari Marg, New Delhi.

Sub: Regarding issuing of FSC in r/o Elisabeth Gauba School, Sector-II, DIZ, Area, Kali Bari Marg, New Delhi.

Sir,

This has reference to your mail id <theelisabethgaubaschool@gmail.com> dated 07/02/2025, on the subject cited above. In this regard, it is to inform you that the site was inspected by officer concerned of this department on 21.03.2025 in the presence of Mrs. Monica Rao and the following shortcomings are observed.

1. Alternate staircase of 0.80 m serving to basement not provided.
2. Terrace Pump not in auto mode provision.
3. Further, undertaking regarding use of basement as per sanctioned plan is required to be submitted.

In view of above, fire safety certificate (FSC) cannot be considered at this stage. Therefore, it is requested to rectify the above shortcomings at the earliest for further consideration in the matter.

Yours faithfully,

(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to:-

1. The Director (Education), Govt. of NCT, Old Sectt. Delhi - 54.