

C/30

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No. F6/DFS/MS/School/2025/SZ/613

Dated: 07/08/2025

To,

The Principal,
G.B.M. Public School,
Shivani Enclave, Ph- I,
Kakrola, New Delhi- 110078.

Sub: -Regarding renewal of "FSC" from fire safety point of view in r/o G.B.M. Public School at Shivani Enclave, Ph- I, New Delhi- 110078.

Sir,

Please refer to your letter No. GBMPS/FIRE/6/2025/381, dated 30.06.2025, on the subject cited above. In this connection, it is to inform you that officer concerned of this department inspected the school building on dated 21.07.2025 to verify the fire safety arrangements in accordance with the rules. At the time of inspection Vice Principal of the school was present and it was observed that the previously, this department issued FSC vide letter No. F.6/DFS/MS/School/2022/738 dated 06.07.2022 for building comprised of ground plus one upper floor only but now school management constructed one more floor. (i.e. 2nd floor) and buildings comprised of ground plus two upper floors, and have following shortcomings:-

1. One of the staircases having width of 1.35 m for 1st to 2nd to be made wide to 1.50 m up to 2nd floor.
2. Hose reels found provided at ground and 1st floor and same may be extended up to 2nd floor.
3. Terrace fire pump of 450 LPM found not provided.
4. Overhead water storage tank of 10,000 ltrs. found not provided.
5. Exit signage's are not provided.

In view of the above, renewal of 'Fire Safety Certificate' cannot be granted at this stage. You are requested to rectify the above-mentioned shortcomings under intimation to this department for taking further necessary action in this matter and running school in absence of requisite fire safety arrangements shall be at the risk & liability of the school management.

Yours faithfully


(Virendra Singh)
Chief Fire Officer
Delhi Fire Service

Copy to:-

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054