



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**



No. F.6/DFS/MS/School/2025/SZ/ 699

Dated: 03 / 09 / 2025

To

The Principal,  
G.D. Goenka Public School,  
Sector-10, Dwarka,  
New Delhi-110075

Sub: **Renewal of Fire Safety Certificate in r/o G.D. Goenka Public School at Sector-10, Dwarka, New Delhi-110075**

Sir,

This has reference to your letter No. Nil dated Nil, received in this department vide outdoor diary No. 4642 dated 07/08/2025. In this connection, it is to inform you that the premise was inspected by the concerned officers of this department on 20/08/2025 in the presence of Smt. Vimla Bist (Vice Principal). During course of inspection, the shortcomings observed are as below.

1. Fire/Smoke check doors at some locations found damaged/removed.
2. Horizontal & vertical opening at some levels found unsealed.
3. Some of portable fire extinguisher found unrefilled/empty, damaged.
4. Automatic fire detection and alarming system found non-functional.
5. Manually operated electrical fire alarm system found non-functional.
6. Automatic sprinklers system needs to be extended in left-out area.
7. Main & standby diesel operated fire pump found non-functional.
8. Exit signage found removed at some places.
9. Storage under staircase is considered hazardous from fire safety point of view.
10. Basement found used for school activity and cultural program, which should be verified by MCD.
11. Lift was seen under repair/renovation. It may be clarified, if lift is being used or not.
12. Hose Reel & Hydrant provided but not functional.

In view of the above shortcomings, application for renewal of fire safety certificate cannot be considered at this stage. You are advised to submit compliance of the shortcomings above for further action in the matter.

Yours faithfully,

(Virendra Singh)  
Chief Fire Officer  
Delhi Fire Service

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.