



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आजादी का
अमृत महोत्सव
C-41

No. F6/DFS/MS/2025/WZ/ 740

Dated:- 18/09/2025

To,

The Principal,
G. D. Goenka Public School,
A-2, Paschim Vihar,
Near A-1, Gurudwara, Delhi-110063.

Subj:- Regarding renewal of Fire Safety Certificate in respect of G. D. Goenka Public School
Located at A-2, Paschim Vihar, near A-1, Gurudwara, Delhi-110063

Sir,

This has reference to your email dated 02/08/2025, on the subject cited above. In this connection, it is to inform you that the said school building was re-inspected by the officer concerned of this department on 02/09/2025 in the presence of Sh. Ashish Juyal (LDC) & Sh. Manoj Kumar (Estate Manager). During the inspection, it was observed that the building is comprised of Ground + 03 Upper Floors. However, the following shortcoming has been observed:-

1. 04 nos. new classrooms found added on each floor in north wing portion of building to be regularized by MCD department/submit sanctioned plan for addition/alteration.
2. Rooms constructed on terrace floor with temporary roof of Cement-Sheet to be demolished.
3. Existing multipurpose hall constructed with temporary structure to be regularized/sanctioned by building department i.e. MCD and stop to use immediately as same found occupied during inspection.

In view of the above shortcoming, the application for renewal of Fire Safety Certificate cannot be considered at this stage & rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

Virendra Singh
17/9/25

Virendra Singh
Chief Fire Officer

87C
16/09/25

Copy to:-

1. The Deputy Director, Delhi Municipal Corporation, Civic Centre, Minto Road, Delhi-110002