

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/2025/School/WZ/268

Dated: 19/03/2025

**FIRE SAFETY CERTIFICATE**

Certified that the **G.D. Goenka Public School, Pkt-04, Sector-9, Rohini, Delhi-110085**, comprised of **Ground + 03 upper floors** has already been issued FSC by this department vide letter No. **F.6/DFS/MS/2022/School/WZ/238** dated **07.03.2022**. The premises was re-inspected by the officer concerned of this department on **06.03.2025** in the presence of **Mr. Mukesh (Administrator)** and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class **Educational "Group B"** with effect from 19/03/2025 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 19/03/2025 at New Delhi by

(Atul Garg)  
**DIRECTOR**  
 Ph: 011-23414000

Copy to :-

1. The Principal, G.D. Goenka Public School, Pkt-04, Sector-9, Rohini, Delhi-110085.
2. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.

**Conditions for the validity of fire safety certificate:**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. The owner/ occupier shall submit a declaration **every year** in **Form 'K'** [sub rule (2) of Rule 38] provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [http://delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Forms](http://delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms)
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction (Clause 2.9.2 of UBBL-2016) or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of Rule 37] along with a copy of this Certificate, **six months** prior to its expiry."
8. Smoke management system shall be resumed provided/within in six months from date of issue of this certificate, failing which FSC shall be considered null & void.



**INSPECTION REPORT**

1. Name & address of the building : G. D. Goenka Public School, Pkt-04, Sector-9, Rohini, Delhi-110085.
2. Type of Occupancy : Educational
3. Type of Case : Renewal (Ground + 03 upper Floors)
4. Details of previous NOC : F.6/DFS/MS/2022/School/WZ/238 dated 07.03.2022
5. Fire Safety directives letter No : NBC Part-4
6. Date of inspection : 06.03.2025
7. Name of the Inspecting Officers : A.K.Sharma ADO (Rohini)
8. Name and designation of officers from the building side : Mr. Mukesh (Administrator)
9. Year of Construction : 2005-2009
10. Applicant's letter No. : OD No.05.03.2025

	Minimum Standards on fire prevention and fire safety U/R 33	Director of Education letter dated 17.01.2005	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	Accessible	Accessible	MR
	• Gate width	Accessible	5m	MR
	• Width of internal road	-NA-	-NA-	-NA-
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	02nos.	02nos.	MR
	• Basements	-NA-	-NA-	-NA-
	b. Width of staircases			
	• Upper Floors	1.50m	1.42m & 1.43m	MR(old case)
	• Basements	-NA-	-NA-	-NA-
	c. Protection of exits			
	• Fire check door	-NA-	-NA-	-NA-
	• Pressurization	-NA-	-NA-	-NA-
	d. No. of continuous staircases to terrace	-NA-	-NA-	-NA-
	e. Width of Corridor	-NA-	-NA-	-NA-
	f. Door Size	1 m	1.0m with door frame	MR(old case)
3	<b>Compartmentation.</b>			
	• Fire check door	-NA-	-NA-	-NA-
	• Sealing of electrical shafts	-NA-	-NA-	-NA-
	• Fire Rating of shaft door	-NA-	-NA-	-NA-
	• Water Curtain	-NA-	-NA-	-NA-
	• Fire Dampers	-NA-	-NA-	-NA-
4	<b>Smoke Management System.</b>			
	• Basements	-NA-	-NA-	-NA-
	• Upper floors	12 a/c per hour	Natural Ventilated/Exhaust fan found removed	MR (will be provided in six months)
5	<b>Fire Extinguishers</b>			
	• Total numbers	16 nos	Provided	MR
	• Types	ABC/Co2	ABC-20	MR
	• ISI marking	ISI Marked	Yes	MR
6	<b>First-Aid Hose Reels.</b>			
	• Total numbers on each floor	02nos.	02nos.	MR
	• Length of hose reel hose	30m	30m	MR
	• Nozzle diameter	5mm	5mm	MR
7	<b>Automatic fire detection and alarming system.</b>			
	• Type of detectors	-NA-	-NA-	-NA-
	• Location of Main Panel	-NA-	-NA-	-NA-



	<ul style="list-style-type: none"> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	-NA-	-NA-	-NA-
8	MOEFA	Required	Provided	MR
9	Public Address System.			
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
11	Internal Hydrants			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	100mm	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> <li>Ground Level <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/ Manual stopping</li> <li>Pump House Access</li> </ul> </li> <li>Terrace level <ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power Supply</li> <li>Auto Starting of pump</li> </ul> </li> </ul>	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		225lpm	225lpm	MR
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		450lpm & 220 lpm	450lpm & 220 lpm	MR
		40m	40m	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> <li>Underground tank capacity</li> <li>Draw-off connection</li> <li>Fire service inlet</li> <li>Access to tank</li> <li>Overhead Tank capacity</li> </ul>	NA	Provided	NA
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		10,000 ltrs	10,000ltrs	MR
		Required	Provided	MR
15	Exit Signage.			
16	Provision of Lifts.			
	<ul style="list-style-type: none"> <li>Pressurization of Lift Shaft</li> <li>Pressurization of Lift lobby</li> <li>Communication In lift Car</li> <li>Fireman's Grounding Switch</li> <li>Lift Signage</li> </ul>	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
17	Standby power supply	-NA-	-NA-	-NA-
18	Refuge Area.			
	<ul style="list-style-type: none"> <li>Total Area</li> <li>Location</li> </ul>	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
19	Fire Control Room			
	<ul style="list-style-type: none"> <li>Detector System Panel</li> </ul>	-NA-	-NA-	-NA-

N/20

	• Flow Switch Panel	-NA-	-NA-	-NA-
	• PA System Panel	-NA-	-NA-	-NA-
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F.6/DFS/MS/2022/School/WZ/238 dated 07.03.2022 is recommended for renewal under rule 37 of the Delhi Fire Service rules 2010.

*[Signature]* 7/3/25

Signature of the Inspecting Officer  
Name Ajay Kumar Sharma  
Designation ADO(Rohini)

DO (NW)

*[Signature]*  
11/03/2025

Dy CFB 11/03/25

*[Signature]*  
11/3

11.34-NW

11/03/25...

CFO

*[Signature]*  
12/3/2025

Director

*[Signature]*  
13/03/25

*[Signature]*

Fi letter is put up for Kinn  
perusal and signature please

*[Signature]*  
18/03/25

*[Signature]*  
18/3/25