

c 167



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/School/WZ/2025/646

Dated:- 13/05/2025

FIRE SAFETY CERTIFICATE

Certified that the **G.D. Goenka Public School**, Located at **Main Rohtak Raod**, Opposite Metro Pillar No. 497, Mundka, New Delhi-110041, running at basement + ground + 01 upper floor only in a building comprised of basement + ground + 02 upper floors, owned/occupied by **G.D. Goenka Public School** have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officer concerned of Fire Service on 29/04/2025 in the presence of Sh. Naveen Kumar Lakra (Chairman) and that the building/premises is fit for occupancy class **"Educational Building" Group-B (Basement + Ground + 01 Upper Floor only)** with effect from 13/05/2025 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf.

Issued on ...13/05/2025... at New Delhi by


 (Atul Garg)
 Director

Tel. No. 011-23414000

Copy to:-

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi - 110054
2. The Principal, G.D. Goenka Public School, Main Rohtak Road, Opposite Metro Pillar No. 497, Mundka, New Delhi-110041.

Qc 812
 12/05/25

Conditions for the validity of fire safety certificate:-

1. This FSC is valid for basement, ground & one upper floor only.
2. All the means of escape shall be kept free of all type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
5. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
6. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
7. All comments / directions of licensing Department shall always be permitted and followed.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
9. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.
10. The basement shall be used as per UBBL.
11. The school management has given an undertaking that the building was initially constructed with double basement with ground plus two stories but during construction, second basement was filled and sealed. And on second floor renovation work is going on & during occupancy of the school renovation work will not be carried out. If found the same FSC shall be treated as null & void.

INSPECTION REPORT

1. Name and address of the building: G.D. Goenka Public School, located at Main Rohtak Road, Opposite Metro Pillar No. 497, Mundka, New Delhi-110041
2. Type of Occupancy : Educational,
3. Type of Case : New
4. Details of previous NOC : Nil
5. Fire Safety directives Letter No. : Nil
6. Date of inspection : 29/04/2025
7. Name of the Inspecting Officer : Aman Kumar Lathar, ADO (JWP)
8. Name and designation of Officer
from the building side : Naveen Kumar Lakra (Chairman)
9. Year of Construction : 2004
10. Applicant's letter No. : nil dated 22/04/2025
- The building is comprised of basement, ground plus two upper floors but school is running at basement, ground plus one upper floor only.

S No	Minimum standards on fire prevention and fire safety U/R 33	D.O.E. Cr. No. 3298-3398 dated 01/03/2011 Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 m	Provided	MR
	• Gate width	4.5 m	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	03 nos.	Provided	MR
	• Basements	03 nos.	Provided	MR
	b. Width of staircases			
	• Upper floors	1.5 m each	1.63 to 1.75 m x 2 (B to Terrace) 1.63 to 1.75 m x 1 (G to Terrace)	MR
	• Basements	1.5 m each	1.63 to 1.75 m x 2 (B to Terrace) Ramp-02 (3.81 m & 4.14 m)	MR
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	02	Provided	MR
	e. Width Of Corridor	1.5 m	2.20 m	MR
	f. Door Size	1.2 m	Provided	MR
3.	Compartmentation		NA	
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA

4.	Smoke managements System			
	• Basements	Required	Exhaust Fan	MR
	• Upper floors	Required	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	20 nos.	30 nos.	MR
	• Types	ABC & CO ₂	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	02	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level	NA	2280 lpm	NA
	• Discharge of main pump	NA	70 m	NA
	➤ Head of main pump	NA	01	NA
	➤ Number of main pumps	NA	180 lpm	NA
	➤ Jockey pump out put	NA	70 m	NA
	➤ Jockey pump head	NA	Provided	NA
	➤ Standby Pump out put	NA	Provided	NA
	➤ Standby Pump Head	NA	Provided	NA
	➤ Auto Staring/Manual stopping	NA	Provided	NA
	➤ Pump House Access	NA	Provided	NA
	• Terrace level			
	➤ Discharge of pump	450 lpm x 2	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	15,000 ltrs.	Provided	MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA

	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

Note:- The school management has given an undertaking that the building was initially constructed with double basement with ground plus two stories but during construction, second basement was filled and sealed. And on second floor renovation work is going on & during occupancy of the school renovation work will not be carried out. If found the same FSC shall be treated as null & void.

Keeping in view of substantial compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, grant of Fire safety Certificate is recommended under the rule 35 of the Delhi Fire Service Rules, 2010 under the DFS Act 2007.

Accordingly DFA is put up for approval please.

Q111-ta 11
05/05/25
Aman Kumar Lathar
ADO (JWP)

D. C. P. / 627

dy
6/5/2025

CFD /
7/5/2025

Director
8/5/25

MD / JWP

Sir, F.T. letter is put-up for your signature 10/

Director
MD

Q111-ta 11
12/05/25
ADO (JWP)