



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7/5
आफादीक
अमृत महोत्सव

No. F6/DFS/MS/GH/NDZ/2025/ 310

Dated: 06/05/2025

FIRE SAFETY CERTIFICATE

Certified that the M/s Geesons Guest House located at 65, D.B.G. Road, Pahar Ganj, New Delhi, comprised of Ground + 04 upper floors: Ground floor - Reception + lobby, 1st floor - 03 Guest rooms + 02 Hall + Office, 2nd floor to 3rd floor - 10 Guest rooms + 01 store + 01 staff room at each floor, 4th floor- closed (an affidavit dated 10.12.2019 not to use any floor above third floor has been submitted by the owner), was granted Fire Safety Certificate (FSC) by this department vide letter no. F.6/DFS/MS/GH/2022/NDZ/321 dated 01.07.2022 for total for 23 guest rooms. The premises was re-inspected by officer concerned of this department on 28.04.2025 in presence of manager and found that guest house has complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010. Accordingly, the Guest House is fit for occupancy of Group 'A (Residential) sub division A-1, total 23 guest rooms (1st floor -03 Guest rooms, 2nd floor to 3rd floor - 10 Guest rooms at each floor) with effect from 06/05/2025 and valid upto 31.03.2028 in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to conditions under Rule 38 of Delhi Fire service Rules, 2010 printed below.

Issued on06/05/2025.....at New Delhi by

(Atul Garg)
Director
Delhi Fire Service
20/4 30/4

Reference: elt.mcdonline application no. 2025041206262.

Copy to-

1. The Commissioner, MCD, Dr. S.P.M. Civic Centre, Minto Road, New Delhi-110002:- To ensure the occupancy as detailed above.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The means of escape shall be kept unobstructed/unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub Rule (I) of Rule 37] along with a copy of this Certificate, six month prior to its expiry. Any change in the occupancy shall be intimated to this Deptt. and approval shall be obtained thereto before occupancy of the same.
9. The number of lodgers shall not exceed 10 persons per floor.

INSPECTION REPORT

1	Name & address of the building	M/s Geesons Guest House located at 65, D.B.G. Road, Pahar Ganj, New Delhi.			
2	Building is comprised of	Ground + 04 upper floors Ground floor - Reception + lobby 1 st floor - 03 Guest rooms + 02 Halls + Office 2 nd floor - 10 Guest rooms + 01 store + 01 staff room. 3 rd floor - 10 Guest rooms + 01 store + 01 staff room. Fourth floor - closed as per the affidavit dated 10.12.2019 not to use any floor above third floor submitted by the owner			
3	Type of occupancy	Residential Sub Division- A-1			
4	Type of case	Renewal			
5	Details of previous FSC	F.6/DFS/MS/GH/2022/NDZ/321 dated 01.07.2022			
6	Fire safety directive letter no.	Nil			
7	Date of inspection	28.04.2025			
8	Name of the inspecting officers	Rajesh Kumar Shukla, ADO (M. Road)			
9	Name of the designation of officer From the building side	Sh. Manish Aggrawal (Owner)			
10	Year of construction	2007			
11	Applicant's letter no.	elt.mcdonline application no. 2025041206262.			
S. No	Minimum standard of Fire Prevention and Fire Safety U/R 33	Requirement as per Rule 35 (6)	Provide at site	Remarks MR/NMR	
1	Access to Building				
	A	Road width	NA	6.0 m	NA
	B	Gate width	NA	NA	NA
	C	Width of internal roads	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits				
	A	No. of staircase:			
		a) Upper floor	1 no.	1 no.	MR
		b) Basements	NA	NA	NA
	B	Width of the staircase:			
		a) Upper floors	0.80 m	1.22 m to 1.25 m	MR
		b) Basements	NA	NA	NA
	C	Protection of exits			
		a) Fire check door	NA	NA	NA
		b) Pressurization	NA	NA	NA
	D	No. of continuous staircase to terrace:	1 no.	1 no.	MR
	E	Width of the corridor	NA	NA	NA
	F	Door size	1.0 m	1.0 m	MR
3	Compartmentation:				
	A	Fire check doors	NA	NA	NA
	B	Sealing of horizontal & vertical opening	NA	NA	NA
	C	Fire rating of shaft doors	NA	NA	NA
	D	Water curtain	NA	NA	NA
	E	Fire dampers	NA	NA	NA
4	Smoke Management System:				
	A	Basements	NA	NA	NA
	B	Upper floors	Required	Natural/Exhaust Fans	MR
5	Fire Extinguishers				
	A	Total numbers	15 nos.	15 nos.	MR
	B	Types	CO ₂ , ABC	CO ₂ , ABC	MR
	C	ISI marking	Required	Provided	MR

2/27

6	First Aid Hose Reel				
	A	Total no. at each floor	1 no.	1 no.	MR
	B	Length of hose reel	30 m	30 m	MR
	C	Nozzle diameter	5 mm	5 mm	MR
7	Automatic Fire Detection and Alarm System (ADAS) (Required as per clause 7.31.viii, UBBL 2016).				
	A	Type of detectors	CO detector	Provided	MR
	B	Location of main Panel	At ground	Provided	MR
	C	Location of repeater panel	NA	NA	NA
	D	Alternate power source	Required	Provided	MR
	E	Hooter's location	Required	Provided	MR
8	MOEFA		NA	NA	NA
9	Public Address System		Required	Provided	MR
10	Automatic Sprinkler System				
	A	Basement	NA	NA	NA
	B	Upper floor	NA	NA	NA
	C	Sprinklers above false ceiling	NA	NA	NA
11	Internal hydrants				
	A	Size of the riser/down comer	NA	100 mm	NA
	B	No. of hydrants per floor	NA	1 no.	NA
	C	Hose box	NA	1 no.	NA
12	Yard Hydrants				
	A	Total no. of hydrants	NA	NA	NA
	B	Hose box	NA	NA	NA
13	Pumping arrangements				
	A	Ground Level			
		a) Discharge & head of main pump	NA	NA	NA
		b) Number of main pump	NA	NA	NA
		c) Discharge & head of jockey pump	NA	NA	NA
		d) Discharge & head of Standby pump	NA	NA	NA
		e) Auto starting/ manual stopping	NA	NA	NA
	B	Terrace Level			
		a) Discharge of terrace pump	450 LPM	Provided	MR
		b) Head of terrace pump	40 m	Provided	MR
		c) Alternate power supply	Required	Provided	MR
		d) Auto starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting				
	A	Underground tank capacity	NA	NA	NA
	B	Draw off connection	NA	NA	NA
	C	Fire Service Inlet	NA	NA	NA
	E	Access to tank	NA	NA	NA
	D	Overhead tank capacity	10,000 ltrs	Provided	MR
15	Exit Signage		Required	Provided	MR
16	Provision of lift				
	A	Pressurization of lift shaft	NA	NA	NA
	B	Pressurization of lift lobby	NA	NA	NA
	C	Communication in lift car	Required	Provided	MR
	D	Fireman switch	Required	Provided	MR
	E	Lift signage	Required	Provided	MR
17	Standby Power Supply		Required	Provided	MR

N/28

M/s Geesons Guest House located at 65, D.B.G. Road, Pahar Ganj, New Delhi.

18	Refuge Area			
A	location	NA	NA	NA
B	Total area	NA	NA	NA
19	Fire Control Room			
A	Fire Detection System panel	NA	NA	NA
B	Flow switch panel	NA	NA	NA
C	P A system panel	NA	NA	NA
D	Battery backup	NA	NA	NA
E	Building floor plan	NA	NA	NA
20	Special Fire Protection for special risk if any			
A	Special Fire Protection system for Protection of Special Risk, if any:	NA		

LEGENDS:- Meeting Requirement (MR), Not Meeting Requirement (NMR), Not Applicable (NA), Provided but Not Functional (PNF), Not Provided (NP).

Note: The last FSC had been issued for total 23 guest rooms with 26 beds (1st floor- 03 guest rooms with 06 beds, 2nd floor - 10 guest rooms with 10 beds, 3rd floor- 10 guest rooms with 10 beds) but the present application has been applied for 27 guest rooms with 54 beds (1st floor - 3 guest rooms with 6 beds, 2nd floor to 3rd floor - 12 guest rooms with 24 beds at each floor. However, the owner has submitted an affidavit/ undertaking that same has been mentioned by mistake and has requested that the previous FSC may be renewed without any change. Accordingly, the inspections have been conducted and case is being proposed.

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspections.

In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the Rules, the FSC issued vide letter no. F.6/DFS/MS/GH/2022/NDZ/321 dated 01.07.2022 is recommended to be renewed under Rule 37 of the Delhi Fire Service Rules 2010.

Signature of the Inspecting Officer
Name Rajesh Kumar Shukla
Designation ADO (M. Road)

DO (CD)

DO
30/4/25

Dy. C.F.O. (M.R.)

R.K.P.
30/04/25C.F.O.
01/05/2025Director
6/5/25

m

V. Handal
06/5/25

Q