



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No: F.6/DFS/MS/School/2025/WZ/ 651

Dated: 18/08/2025

To,

The Principal,
 Geetanjali Public School,
 Dulia Colony, Alipur, Delhi-110036.

Sub: Regarding issuance of Fire Safety Certificate in r/o Geetanjali Public School located at Dulia Colony Alipur, Delhi- 110036.

Sir,

This has reference to your letter no. nil received through outdoor diary no. 3010 dated 24.06.2025 on the subject cited above. In this connection, it is to inform you that the above said school building was inspected by the officer concerned of this department on 29.07.2025 to ascertain the availability and operability of the fire prevention and fire safety measure, Sh. Vishu Tomar was present at the time of inspection. During the course of visit it was observed that school is running on ground, first floor and second floor is used as owner residence.

Your request for **issuance of FSC is rejected** due to the following shortcoming:-

1. Road width found 4.5 m against the required width of 6 m.
2. Width of staircases found 1 m & 0.85 m against the requirement of both staircases having 1.5 m width each.
3. Class room door width found 0.90 m against the required width of 1 m.
4. Fire extinguishers not provided.
5. Exit signages not provided.
6. Building plan on a scale of 1:100 duly signed by registered architect and owner not provided.

You are advised to rectify the above-mentioned shortcomings under intimation to this department.

Yours Faithfully

(Virendra Singh)
 Chief Fire Officer

Copy to:-

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.